

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters		Biotowers				
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Mon	3.6					0.00	7.52	125	91	20.90	7.23	90	82	15.20	7.14	15	22	10.09	4.6		2.1		0.87	5.7	0.58	
2	Tue	3.7		0.07			0.00	7.38	115	140	14.30	7.26	93	90	17.80	7.13	18	22	13.30	4.6		2.3		0.87	5.5	0.50	
3	Wed	3.6				0.4	0.00	7.43	98	94	13.30	7.36	107	86	17.25	7.32	18	24	11.20	4.4	40	2.4		0.85	5.5	0.52	
4	Thu	3.7					0.00	7.37	120	140	14.50	7.29	116	100	21.30	7.18	17	29	13.90	4.6		2.3	90	0.86	5.5	0.50	60
5	Fri	3.7		0.07			0.00	7.45	130	152	10.70	7.39	93	93	14.90	7.37	13	19	11.60	4.6		1.9		0.74	5.4	0.44	
6	Sat	3.7	3.7				0.00	7.43	105	100	11.85	7.46	77	92	14.90	7.43	12	18	10.00	4.6		1.8		0.71	5.4	0.47	
7	Sun	3.5					0.00	7.40	110	72	10.80	7.18	85	68	11.90	7.15	14	14	7.72	4.6		1.8		0.79	5.5	0.55	
8	Mon	3.5					0.00	7.38	89	111	13.70	7.23	86	78	14.60	7.15	14	20	10.16	4.6		2.1		0.89	5.6	0.59	
9	Tue	3.7		0.37			0.00	7.32	120	96	13.90	7.21	80	70	14.70	7.16	12	17	10.20	4.6		2.3		0.84	5.4	0.47	
10	Wed	3.6		0.20			0.00	7.29	120	124	15.20	7.27	95	93	17.90	7.29	15	19	12.30	4.6		2.3		0.92	5.5	0.54	
11	Thu	3.7					0.00	7.33	107	104	16.60	7.27	93	76	18.50	7.23	15	19	14.10	4.6		2.3		0.85	5.5	0.50	
12	Fri	3.6					0.00	7.60	96	106	36.80	7.61	92	80	23.20	7.64	18	20	16.60	4.6		2.0		0.80	5.5	0.50	
13	Sat	3.5	3.6				0.00	7.28	77	106	16.25	7.22	80	68	17.00	7.19	15	18	11.80	4.6		1.8		0.86	5.5	0.59	
14	Sun	3.5					0.00	7.38	95	100	16.60	7.36	78	64	16.95	7.39	14	17	11.80	4.7		1.9		0.91	5.5	0.58	
15	Mon	3.6		0.08			0.00	7.43	98	104	16.70	7.32	80	70	18.10	7.29	13	16	11.80	4.6		2.1		0.87	5.5	0.55	
16	Tue	3.5		0.05			0.00	7.38	92	138	14.90	7.36	67	76	17.40	7.40	11	18	13.00	4.6		2.3		0.93	5.4	0.53	
17	Wed	3.6					0.00	7.38	225	170	15.00	7.37	110	78	17.60	7.35	14	15	12.70	4.6		2.3		0.90	5.5	0.51	
18	Thu	3.9					0.00	7.40	107	160	19.10	7.32	78	78	18.30	7.29	11	18	14.60	4.6		2.3		0.78	5.6	0.44	
19	Fri	3.6					0.00	7.57	160	164	30.90	7.31	88	87	19.10	7.33	14	21	15.30	4.6		1.9		0.79	5.5	0.51	
20	Sat	3.5	3.6	0.05			0.00	7.35	107	102	13.80	7.19	95	76	14.00	7.18	16	21	10.30	4.6		1.8		0.81	5.4	0.54	
21	Sun	4.6		0.13			0.00	7.38	85	80	10.10	7.33	68	82	12.45	7.26	17	26	10.00	4.7		2.2		0.47	5.9	0.27	
22	Mon	6.2		0.32		1.4	0.00	7.40	87	139	11.10	7.29	68	114	11.40	7.29	22	38	9.04	5.7		2.9		0.38	6.8	0.08	
23	Tue	4.0		0.05			0.00	7.39	92	82	12.50	7.30	70	76	14.70	7.26	17	22	11.60	4.6		2.3		0.74	5.5	0.39	
24	Wed	3.5		0.16		0.3	0.00	7.41	99	90	14.50	7.26	88	77	17.50	7.23	15	22	14.00	4.5		2.3	120	0.94	5.5	0.57	
25	Thu	3.6		0.01			0.00	7.48	104	90	16.30	7.43	94	74	20.00	7.46	16	16	13.00	4.6		2.3		0.90	5.6	0.53	
26	Fri	3.5		0.13			0.00	7.56	103	92	16.20	7.47	87	78	20.10	7.50	17	21	12.70	4.6		1.9		0.87	5.5	0.57	
27	Sat	3.7	4.2	0.12			0.00	7.58	98	104	13.75	7.58	79	68	16.60	7.61	17	15	12.40	4.6		1.8		0.72	5.5	0.47	
28	Sun	4.2		0.03			0.00	7.49	97	110	11.90	7.46	65	78	13.85	7.43	19	20	10.50	4.6		2.1		0.61	5.7	0.37	
AVERAGE		3.8		0.07		0.1	0.00	7.42	109	113	15.79	7.33	86	80	16.69	7.31	15	20	11.99	4.6	1	2.1	8	0.80	5.6	0.49	2
MAXIMUM		6.2	4.2	0.37		1.4	0.00	7.60	225	170	36.80	7.61	116	114	23.20	7.64	22	38	16.60	5.7	40	2.9	120	0.94	6.8	0.59	60
MINIMUM		3.5		0.01		0.0	0.00	7.28	77	72	10.10	7.18	65	64	11.40	7.13	11	14	7.72	4.4	40	1.8	90	0.38	5.4	0.08	60
# OF DATA		28		15		28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	1	28	2		28		1
TOTAL		106		1.84		2	0	208	3060	3161	442	205	2401	2252	467	205	429	567	336	129	40	59	210		156		60

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date: Feb-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	Maximum Daily pH	Minimum Daily pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Mon	2.7	7.42	7.18	< 2		30		3		90		0.22		7		10.5				
2	Tue	2.8	7.28	6.88	2		64		4		107		0.27		8		10.3				
3	Wed	2.8	7.28	6.83	< 2		30		4		121		0.27		8		10.3				
4	Thu	2.8	7.25	6.84	< 2		31		9		277		0.34		10		10.3				
5	Fri	2.8	7.29	6.95	< 2		31		2		62		0.30		9		10.1				
6	Sat	2.8	7.33	6.80	< 2	1	31	40	4	4	124	118	0.22	0.26	7	8	10.2				
7	Sun	2.6	7.32	6.84	< 2		30		2		44		0.17		5		10.2				
8	Mon	2.6	7.27	6.96	2		65		6		176		0.18		5		10.2				
9	Tue	2.8	7.28	6.93	2		62		6		186		0.26		8		10.3				
10	Wed	2.7	7.25	6.91	< 2		30		2		59		0.32		10		10.4				
11	Thu	2.8	7.29	6.92	3		83		3		92		0.52		16		10.2				
12	Fri	2.8	7.80	6.92	< 2		30		5		152		0.35		11		10.3				
13	Sat	2.6	7.17	7.01	2	2	61	51	4	4	115	118	0.32	0.30	9	9	10.1				
14	Sun	2.6	7.35	7.04	< 2		29		5		144		0.21		6		10.3				
15	Mon	2.7	7.38	7.00	< 2		30		3		89		0.22		7		10.1				
16	Tue	2.7	7.40	7.04	< 2		30		4		103		0.29		9		10.0				
17	Wed	2.8	7.36	6.96	2		60		4		120		0.28		8		10.1				
18	Thu	3.0	7.22	6.78	< 2		32		2		48		0.54		17		10.3				
19	Fri	2.8	7.34	7.10	2		61		2		61		0.81		25		10.2				
20	Sat	2.7	7.27	6.90	< 2	1	29	39	7	4	206	110	0.37	0.39	11	12	10.0				
21	Sun	3.7	7.38	6.84	3		124		12		445		0.31		12		10.2				
22	Mon	5.2	7.39	6.97	5		265		8		416		0.67		35		10.4				
23	Tue	3.1	7.23	7.01	3		106		3		82		0.49		16		10.3				
24	Wed	2.7	7.33	7.04	2		62		4		117		0.40		12		10.4				
25	Thu	2.9	7.36	7.10	2		61		4		121		0.47		14		10.2				
26	Fri	2.8	7.39	7.01	2		61		7		205		0.51		15		10.1				
27	Sat	2.9	7.75	7.07	2	3	71	107	2	6	62	207	0.43	0.47	13	17	10.1				
28	Sun	3.4	7.45	6.94	4		133		6		192		0.45		16		10.0				
AVERAGE		2.9			2		62		4		144		0.36		12		10.2				
MAXIMUM		5.2	7.80		5	3	265	107	12	6	445	207	0.81	0.47	35	17	10.5				
MINIMUM		2.6		6.78	<2		29		2		44		0.17		5		10.0				
# OF DATA		28	28	28	28		28		28		28		28		28		28				
TOTAL		81	206	195	52		1730		124		4019		10		329		286.1				

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-10

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection						Primary & Secondary Settling			Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day		Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)	
1	Mon						29	3	275	6	2	85	
2	Tue						33	2	278	6	2	85	
3	Wed						34	0	292	6	2	84	
4	Thu						32	0	273	6	2	84	
5	Fri						32	0	298	6	2	85	
6	Sat						31	0	289	6	2	89	
7	Sun						35	0	293	6	2	86	
8	Mon						32	0	291	6	2	94	
9	Tue						31	0	292	6	2	103	
10	Wed						26	0	281	6	2	106	
11	Thu						28	0	281	6	2	90	
12	Fri						26	2	294	6	2	89	
13	Sat						26	0	287	6	2	86	
14	Sun						26	0	282	6	2	87	
15	Mon						25	0	264	6	2	91	
16	Tue						24	0	285	6	2	84	
17	Wed						30	0	288	6	2	85	
18	Thu				27	34	28	0	289	6	2	84	
19	Fri						31	0	275	6	2	85	
20	Sat						24	0	292	6	2	84	
21	Sun						35	0	292	6	2	84	
22	Mon						38	0	296	6	2	85	
23	Tue						21	0	253	6	2	84	
24	Wed					27	23	0	297	6	2	89	
25	Thu						33	0	297	6	2	85	
26	Fri						29	0	299	6	2	84	
27	Sat						34	0	296	6	2	84	
28	Sun						26	0	287	6	2	85	
AVERAGE					1	2	29	0	286	6	2	87	
MAXIMUM					27	34	38	3	299	6	2	106	
MINIMUM					27	27	21	0	253	6	2	84	
# OF DATA					1	2	28	28	28	28	28	28	
TOTAL					27	61	821	6	8015	168	63	2445	

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester				Digested Sludge Storage Tank					
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank #1 Volume (gal x 1000)	Storage Tank #2 Volume (gal x 1000)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)
1	Mon		5.30	63.1	6.52	2.41	61.1	6.91	96				50	23	4.20	60.7	6.95	52	2.54		257		
2	Tue								96				50	20				47	0.50		257		
3	Wed								96				50	19				45			256		
4	Thu								96				50	53				52	1.37		280		25
5	Fri								96				50	23				56	2.28		280		
6	Sat								96				50	36				68			281		
7	Sun								96				50	21				40			281		
8	Mon		3.63	77.8	6.31	2.65	59.2	6.88	96				50	25	3.68	61.6	6.96	54	2.90		281		
9	Tue								96				50	20				45			284		
10	Wed								96				50	36				73			285		
11	Thu								96				50	40				30			308		24
12	Fri								96				50	17				42			307		
13	Sat								96				50	14				24			306		
14	Sun								96				50	16				30	2.92		307		
15	Mon		3.73	78.2	6.49	2.96	58.0	6.87	96				50	38	3.83	62.1	6.95	38			321		14
16	Tue								96				50	12				32	1.87		321		
17	Wed								96				50	18				46			321		
18	Thu								96				50	10				23			310		
19	Fri								96				50	36				28	1.79		327		26
20	Sat								96				50	10				14			327		
21	Sun								96				50	23				58	2.73		328		
22	Mon		3.54	76.9	6.58	2.67	58.1	6.82	96				50	25	4.37	60.4	6.88	58	0.25		301		
23	Tue								95				50	41				76	0.29		298		
24	Wed								96				50	15				32			298		
25	Thu								96				50	23				48	0.21		298		
26	Fri								96				50	15				33			299		
27	Sat								96				50	24				49			299		
28	Sun								96				50	20				46			300		
AVERAGE			4.05	74.0	6.48	2.67	59.1	6.87	96				50	24	4.02	61.2	6.94	44	1.64		297		3
MAXIMUM			5.30	78.2	6.58	2.96	61.1	6.91	96				50	53	4.37	62.1	6.96	76	2.92		328		26
MINIMUM			3.54	63.1	6.31	2.41	58.0	6.82	95				50	10	3.68	60.4	6.88	14	0.21		256		
# OF DATA			4	4	4	4	4	4	28				28	28	4	4	4	28	12	28	28		28
TOTAL			16	296	26	11	236	27	2677				1400	673	16	245	28	1236	20		8315		90

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Feb-10

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l

INFLUENT								EFFLUENT							
Method: 24 hour composite								Site: Post Rake Room							
Site: Post Disinfection															
Sample Characteristics		Cr	Cu	Pb	Ni	Zn	CN, Free	Cr	Cu	Pb	Ni	Zn	CN, Free		
Sample Number															
Sample Type	Permit Condition	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB		
	Monitored	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB		
Frequency	Permit Condition	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual		
	Monitored	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual		
Parameter Limits	Daily Maximum	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
	Monthly Average	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
1st Date:	February 3rd	<0.005	0.049	<0.005	0.005	0.058	<0.005	<0.005	0.013	<0.005	<0.005	0.017	<0.005		
2nd Date:	February 17th	0.0	0.071	<0.005	0.006	0.085	<0.005	<0.005	0.009	<0.005	<0.005	0.013	<0.005		
3rd Date:															
4th Date:															
5th Date:															
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
Average		0.0	0.060	<0.003	0.006	0.072	<0.003	<0.003	0.011	<0.003	<0.003	0.015	<0.003		
Maximum		0.0	0.071	<0.005	0.006	0.085	<0.005	<0.005	0.013	<0.005	<0.005	0.017	<0.005		

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (Colonies /100mL)	Mnthly Av Escherichia Coliform (Colonies /100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	4.2	3.8	3	2	107	62	6	4	207	144	0.47	0.36	17	12	10.0	7.80			
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 7,328

Overall Percent Removal of Volatile Solids 44.6%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 20,251

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 437

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 49

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 723

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 30

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 3

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 3

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	22%	29%	-6%
Secondary Treatment :	82%	75%	28%
Adv. Sec. Treatment :	88%	78%	97%
Overall Treatment :	98%	96%	98%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	3.5	2.0	3.2
Secondary Settling Tank	2.6	1.4	2.4
Final Settling Tank	8.1	4.5	7.4
Chlorine Contact Tank	0.56	0.31	0.51
Total Plant Retention Time	14.3	7.9	13.1

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	780	432	472
Secondary Settling Tank	1030	570	623
Final Settling Tank	525	291	318

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	15	8	9
Secondary Settling Tank	12	7	7
Final Settling Tank	12	7	7

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

2/10/2010 - Successful test of emergency power system

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____

