

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Jan-2008
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters	Biotowers					
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Tue	3.3		0.62			0.00	7.29	150	60	18.20	7.35	76	46	17.60	7.44	14	12	12.20	4.7		2.3		1.10	5.6	0.69	
2	Wed	2.7		0.15			0.00	7.39	89	114	27.85	7.28	106	64	27.80	7.30	14	15	18.30	4.7		2.3		1.61	5.7	1.13	
3	Thu	3.2					0.00	7.27	90	108	21.90	7.26	98	66	24.10	7.24	18	20	19.40	4.7		1.9		1.09	5.8	0.84	
4	Fri	3.8					0.00	7.43	107	136	18.10	7.34	85	79	20.05	7.38	22	32	18.50	4.6		2.0		0.74	6.0	0.57	
5	Sat	4.5	3.3	0.06		0.4	0.00	7.37	125	168	16.90	7.28	101	104	17.80	7.34	21	34	15.00	5.0		2.2		0.60	6.1	0.36	
6	Sun	7.2		0.03		4.7	0.00	7.25	60	86	10.20	7.13	61	74	11.40	7.08	19	29	9.57	6.1		3.1		0.27	7.5	0.04	
7	Mon	5.3		1.50		4.2	0.99	7.50	58	194	9.05	7.28	55	130	9.33	7.10	17	32	7.96	5.1		2.6		0.47	6.5	0.23	
8	Tue	9.5		2.34		16.3	45.90	7.13	22	44	2.65	7.04	19	36	4.01	6.87	8	14	3.17	7.3		3.8		0.16	10.4	0.09	
9	Wed	7.7		0.02			8.06	7.28	48	58	7.44	7.17	43	50	8.74	7.12	11	20	6.59	7.3		3.8		0.45	7.7	0.01	
10	Thu	7.4		0.60		5.1	0.81	7.24	53	100	8.69	7.09	35	64	9.68	6.99	13	25	7.85	5.8		3.6	360	0.29	7.6	0.03	
11	Fri	7.2		0.03			1.07	7.45	47	36	11.28	7.23	45	36	15.35	7.13	13	14	11.94	7.3		3.8		0.53	7.4	0.02	
12	Sat	6.8	7.3				0.00	7.21	50	46	12.23	7.94	53	36	16.42	7.08	14	17	11.64	6.1		3.7		0.45	7.0	0.03	
13	Sun	6.6					0.00	7.16	55	36	12.30	7.10	51	40	15.80	7.14	14	15	10.30	6.0		3.5		0.45	6.8	0.03	
14	Mon	6.4		0.12			0.00	7.23	50	46	14.60	7.22	47	36	17.30	7.27	15	18	11.30	4.8		3.1		0.23	6.8	0.05	
15	Tue	6.2					0.00	7.29	57	56	14.70	7.15	50	50	16.55	7.19	14	19	11.00	4.7		3.1		0.25	6.5	0.04	
16	Wed	4.9					0.00	7.34	71	75	17.80	7.19	69	46	20.10	7.26	16	17	13.70	4.6		2.2		0.42	5.5	0.14	
17	Thu	4.5		0.02			0.00	7.48	92	120	20.30	7.33	73	52	23.60	7.40	15	17	18.00	4.6		2.4		0.58	5.9	0.31	
18	Fri	4.9		0.06			0.00	7.35	77	88	18.50	7.25	58	51	21.30	7.34	16	10	18.90	4.6		1.9		0.33	5.6	0.15	
19	Sat	3.3	5.3	0.05			0.00	7.39	140	84	23.05	7.26	89	52	23.00	7.39	15	13	18.50	4.6		1.7		0.91	5.7	0.71	
20	Sun	3.3					0.00	7.37	99	70	17.80	7.26	86	46	17.90	7.32	19	15	15.00	4.6		1.7		0.91	5.7	0.71	
21	Mon	4.1		0.01			0.00	7.33	107	106	15.20	7.28	65	58	14.80	7.34	17	17	11.85	4.6		2.1		0.63	5.8	0.40	
22	Tue	5.3		0.18			0.00	7.43	105	146	16.80	7.34	64	62	13.90	7.55	18	25	11.35	4.6		3.3		0.51	6.3	0.20	
23	Wed	5.8		0.05			0.00	7.27	87	59	18.70	7.25	62	42	15.30	7.31	13	19	12.60	4.6		2.8		0.27	6.2	0.06	
24	Thu	3.9		0.13			0.00	7.47	103	144	17.50	7.36	78	66	23.00	7.38	15	15	18.30	4.6		2.3		0.77	5.6	0.45	
25	Fri	5.1		0.04			0.00	7.36	89	70	17.10	7.27	59	49	18.70	7.27	18	19	16.20	5.7		3.1		0.74	6.3	0.25	
26	Sat	5.1	4.6	0.04			0.00	7.19	108	104	13.10	7.19	70	50	13.80	7.30	21	19	11.00	4.5		1.8		0.25	5.7	0.12	
27	Sun	5.3					0.00	7.31	98	74	12.90	7.26	73	56	14.70	7.32	20	19	11.80	5.0		2.3		0.37	6.0	0.13	
28	Mon	6.1		0.05		0.9	0.00	7.39	120	314	15.95	7.27	83	196	14.90	7.39	29	42	13.60	5.6		3.0	80	0.41	7.1	0.17	
29	Tue	8.7		0.77		4.7	0.00	7.30	70	204	14.30	7.23	43	86	15.80	7.25	25	27	14.10	7.4		3.9		0.30	8.7	0.00	
30	Wed	6.3		0.01			0.00	7.21	48	76	11.90	7.14	45	52	13.70	7.08	21	23	11.50	5.0		3.4		0.32	6.7	0.06	
31	Thu	6.3	6.3	0.02			0.00	7.22	58	92	13.60	7.30	55	50	15.40	7.16	11	24	14.10	5.5		3.3		0.39	6.6	0.05	
AVERAGE		5.5		0.22		1.2	1.83	7.32	82	100	15.18	7.26	64	62	16.51	7.25	16	21	13.07	5.3		2.8	14	0.54	6.5	0.26	
MAXIMUM		9.5	7.3	2.34		16.3	45.90	7.50	150	314	27.85	7.94	106	196	27.80	7.55	29	42	19.40	7.4		3.9	360	1.61	10.4	1.13	
MINIMUM		2.7		0.01		0.0	0.00	7.13	22	36	2.65	7.04	19	36	4.01	6.87	8	10	3.17	4.5		1.7	80	0.16	5.5	0.01	
# OF DATA		31		23		31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31		2		31		
TOTAL		171		6.90		36	57	227	2533	3114	471	225	1995	1925	512	225	511	636	405	164		86	440		203		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date : Jan-2008

LaPorte Wastewater Treatment Plant

Permit # IN0025577

2101 Boyd Boulevard

Expires 10-31-2009

LaPorte IN, 46350

Certified Operator : Jerry P Jackson

Phone # (219)362-2354

Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Tue	2.8	7.38	3		72		2		55		0.15		4		10.5				
2	Wed	2.3	7.41	< 2		22		2		45		0.18		4		11.0				
3	Thu	2.7	7.16	4		113		6		158		0.46		12		11.0				
4	Fri	3.4	7.30	4		127		8		254		0.84		27		11.5				
5	Sat	3.9	7.46	6	4	213	105	9	5	337	158	0.78	0.38	29	12	10.8				
6	Sun	6.3	7.21	6		379		10		601		0.52		31		10.3				
7	Mon	4.7	7.50	5		224		8		352		0.23		10		10.0				
8	Tue	9.2	7.06	6		446		12		915		0.17		14		10.2				
9	Wed	6.8	7.15	5		294		8		511		0.21		13		10.5				
10	Thu	6.5	7.24	3		190		9		553		0.27		17		10.4				
11	Fri	6.4	7.19	4		260		6		362		0.73		44		11.4				
12	Sat	6.0	7.23	4	5	209	286	8	9	452	535	0.11	0.32	6	19	11.3				
13	Sun	5.9	7.25	4		198		8		413		0.01		1		11.1				
14	Mon	5.8	7.23	4		199		3		161		0.10		5		11.2				
15	Tue	5.6	7.22	4		208		4		182		0.06		3		11.3				
16	Wed	4.4	7.31	3		122		6		243		0.22		9		10.9				
17	Thu	4.0	7.37	3		112		1		19		1.06		39		10.3				
18	Fri	4.4	7.32	3		131		4		163		0.77		31		10.8				
19	Sat	3.0	7.50	3	3	72	149	1	4	28	173	0.19	0.34	5	13	11.1				
20	Sun	3.0	7.56	2		66		3		83		0.54		15		11.3				
21	Mon	3.7	7.35	3		117		8		258		0.51		18		10.5				
22	Tue	4.7	7.40	4		158		4		176		0.24		11		10.6				
23	Wed	5.1	7.46	5		218		4		194		0.16		8		11.6				
24	Thu	3.4	7.38	3		97		3		97		0.63		20		11.0				
25	Fri	4.4	7.33	6		249		5		211		1.94		82		11.0				
26	Sat	4.6	7.23	5	4	195	157	2	4	85	158	0.04	0.58	2	22	12.0				
27	Sun	4.7	7.54	4		195		4		155		0.32		14		11.6				
28	Mon	5.4	7.45	6		295		15		764		0.90		46		10.1				
29	Tue	7.6	7.22	8		593		2		108		1.84		133		10.1				
30	Wed	5.7	7.03	3		180		6		318		0.74		39		11.4				
31	Thu	5.6	7.14	4	6	211	307	4	7	211	339	1.32	1.17	70	62	11.2				
AVERAGE		4.9	7.31	4		199		6		273		0.52		25		10.9				
MAXIMUM		9.2	7.56	8	6	593	307	15	9	915	535	1.94	1.17	133	62	12.0				
MINIMUM		2.3	7.03	<2		22		1		19		0.01		1		10.0				
# OF DATA		31	31	31		31		31		31		31		31		31				
TOTAL		152	227	127		6164		172		8462		16		762		338.0				

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Jan-2008

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection						Primary & Secondary Settling			Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day		Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)	
1	Tue						26	0	284	6	2	94	
2	Wed						26	0	285	6	2	93	
3	Thu						26	0	283	6	2	92	
4	Fri						26	0	279	6	2	92	
5	Sat						26	0	278	6	2	76	
6	Sun						35	0	276	6	2	64	
7	Mon				41	41	31	0	273	6	2	84	
8	Tue				27	34	48	0	271	6		7	
9	Wed						29	0	269	6	1	63	
10	Thu						33	0	268	6	2	68	
11	Fri						28	7	266	6	2	73	
12	Sat						25	0	262	6	2	92	
13	Sun						20	0	260	6	2	91	
14	Mon						20	0	259	6	2	91	
15	Tue						20	0	259	6	2	92	
16	Wed						20	4	259	6	2	90	
17	Thu						20	0	263	6	2	91	
18	Fri						20	0	282	6	2	91	
19	Sat						20	0	283	6	2	91	
20	Sun						20	0	280	6	2	89	
21	Mon						20	0	277	6	2	91	
22	Tue						20	0	275	6	2	90	
23	Wed						20	0	274	6	2	91	
24	Thu						20	0	266	6	2	90	
25	Fri						20	0	260	6	2	90	
26	Sat						20	0	259	6	2	91	
27	Sun						20	0	265	6	2	90	
28	Mon				27	34	28	0	280	6	2	66	
29	Tue						39	2	291	6	0	20	
30	Wed						39	0	302	6	2	91	
31	Thu						31	0	304	6	2	83	
AVERAGE					3	3	26	0	274	6	2	81	
MAXIMUM					41	41	48	7	304	6	2	94	
MINIMUM					27	34	20	0	259	6		7	
# OF DATA					3	3	31	31	31	31	31	31	
TOTAL					95	108	799	13	8490	186	61	2517	

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Jan-2008

LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester				Digested Sludge Storage Tank				
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)	
1	Tue								96				95	19				44	0.14		0.2	
2	Wed								96				95	17				53			0.2	
3	Thu								96				96	19				46	0.01		0.2	
4	Fri								96				96	20				49			0.2	
5	Sat								96				96	13				40			0.2	
6	Sun								96				96	25				61	0.18		0.2	
7	Mon		3.43	77.5	6.32	1.88	54.7	6.80	96	4.79	56.9	7.00	96	29	5.60	54.3	7.04	11		0.2	29	
8	Tue								97				95	35				89			0.2	
9	Wed								96				96	21				59			0.2	
10	Thu								96				96	22				59			0.2	
11	Fri								96				95	26				70			0.2	
12	Sat								96				96	23				54	0.02		0.2	
13	Sun								96				96	6				22			0.4	
14	Mon		2.15	73.4	6.21	1.55	56.8	6.85	96	2.08	53.1	6.99	96	33	5.27	54.3	7.06	26		0.4	29	
15	Tue								96				96	2				0			0.7	
16	Wed								96				96	15				26			0.6	
17	Thu								96				96	13				35			0.5	
18	Fri								96				96	10				28	0.07		0.5	
19	Sat								96				98	13				35	0.22		0.5	
20	Sun								96				98	14				36			0.4	
21	Mon		3.19	71.5	6.32	1.52	57.5	6.82	96	2.61	52.3	6.92	98	23	5.60	55.2	7.04	2		0.3	29	
22	Tue								96				98	5				0			0.2	
23	Wed								96				98	12				39	0.21		0.2	
24	Thu								96				98	13				34			0.2	
25	Fri								96				98	9				34	0.05		0.2	
26	Sat								96				98	11				35			0.2	
27	Sun								96				98	14				38			0.2	
28	Mon		2.54	79.6	6.21	1.90	48.5	6.84	96	2.90	55.4	6.96	98	26	6.10	54.1	6.98	1	0.08	0.2	29	
29	Tue								96				98	22				50			0.1	
30	Wed								96				98	28				79	0.12		0.0	
31	Thu								96				98	26				79	0.16		0.0	
AVERAGE			2.83	75.5	6.27	1.71	54.4	6.83	96	3.10	54.4	6.97	97	18	5.64	54.5	7.03	40	0.11		0.3	4
MAXIMUM			3.43	79.6	6.32	1.90	57.5	6.85	97	4.79	56.9	7.00	98	35	6.10	55.2	7.06	89	0.22		0.7	29
MINIMUM			2.15	71.5	6.21	1.52	48.5	6.80	96	2.08	52.3	6.92	95	2	5.27	54.1	6.98	0	0.01		0.0	
# OF DATA			4	4	4	4	4	4	31	4	4	4	31	31	4	4	4	31	11		31	31
TOTAL			11	302	25	7	218	27	2975	12	218	28	2996	563	23	218	28	1234	1		8	117

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Jan-2008

LaPorte Wastewater Treatment Plant

2101 Boyd Boulevard

LaPorte IN, 46350

Phone # (219)362-2354

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l except mercury (Hg) which is given in ng/l.

INFLUENT									EFFLUENT						
Method: 24 hour composite (except for Hg, which is grab)									Site: Post Cl2 Tank						
Sample Characteristics		Hg	Cr	Cu	Pb	Ni	Zn	CN-	Hg	Cr	Cu	Pb	Ni	Zn	CN-
Sample Number		CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720	CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720
Sample Type	Permit Condition	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
	Monitored	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
Frequency	Permit Condition	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
	Monitored	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
Parameter Limits	Daily Maximum										0.055				0.016
	Monthly Average										0.024				0.016
1st Date:	January 2nd, 2008			0.062							0.015				
2nd Date:	January 9th, 2008		<0.005	0.029	<0.005	0.006	0.045	0.007			0.013				<0.005
3rd Date:	January 16th, 2008			0.044							0.012				
4th Date:	January 23th, 2008		0.008	0.045	<0.005	0.010	0.042	<0.005			0.016				<0.005
5th Date:	January 30th, 2008			0.030							0.010				
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	*See Note	0	NA	NA	0
Average			0.005	0.042	<0.003	0.008	0.044	0.005			0.013				<0.003
Maximum			0.008	0.062	<0.005	0.010	0.045	0.007			0.016				<0.005

* We are currently under Agreed Order 2000-9996-W with IDEM to resolve effluent copper concerns.

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	7.3	5.5	6	4	307	199	9	6	535	273	1.17	0.52	62	25	10.0	7.56			
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Jan-2008
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 4,588

Overall Percent Removal of Volatile Solids 61.2%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 22,057

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 502

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 64

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 850

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 32

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 5

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	21%	38%	-9%
Secondary Treatment :	74%	67%	21%
Adv. Sec. Treatment :	75%	73%	96%
Overall Treatment :	95%	94%	97%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	4.5	1.3	2.2
Secondary Settling Tank	3.3	0.9	1.6
Final Settling Tank	10.5	2.9	5.1
Chlorine Contact Tank	0.72	0.20	0.35
Total Plant Retention Time	18.4	5.2	9.0

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	1193	336	688
Secondary Settling Tank	1575	443	908
Final Settling Tank	803	226	463

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	23	7	13
Secondary Settling Tank	19	5	11
Final Settling Tank	18	5	11

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____



**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
CSO DISCHARGE MONITORING REPORT (CSO DMR)**

STATE FORM 50546 (9-01)

City: La Porte	Page:	1 of 1
Facility: La Porte Wastewater Treatment Facility	Permit Number:	IN0025577
Monitoring Period: (MM/DD/YY to MM/DD/YY)	01/01/2008 01/31/2008	Check box if no CSO discharge occurred for the month:

Design Peak Inf. Flow(MGD) **9.7** Measured/Metered (M) or Estimated (E) must be specified.(Please attach methods used.)

Day of Month	Day of Week	Precip. in Inches	Avg Infl. Flow Rate (MGD)	Peak Infl. Flow Rate (MGD)	CSO Outfall No. 002						CSO Outfall No.						CSO Outfall No.						
					Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	
1	Tue	0.62	3.31	4.40																			
2	Wed	0.15	2.68	4.35																			
3	Thu		3.15	5.15																			
4	Fri		3.80	6.17																			
5	Sat	0.06	4.48	7.60																			
6	Sun	0.03	7.21	10.11																			
7	Mon	1.50	5.27	9.97	9:10		2.9	M	0.99	M													
8	Tue	2.34	9.54	10.04	0:00		24.0	M	45.90	M													
9	Wed	0.02	7.66	9.78	0:00		9.7	M	8.06	M													
10	Thu	0.60	7.37	10.01	6:52		5.1	M	0.81	M													
11	Fri	0.03	7.24	9.99	0:00		14.4	M	1.07	M													
12	Sat		6.77	7.96																			
13	Sun		6.60	7.53																			
14	Mon	0.12	6.44	7.06																			
15	Tue		6.25	7.32																			
16	Wed		4.86	5.65																			
17	Thu	0.02	4.46	6.76																			
18	Fri	0.06	4.89	5.91																			
19	Sat	0.05	3.32	4.05																			
20	Sun		3.30	4.13																			
21	Mon	0.01	4.13	5.86																			
22	Tue	0.18	5.27	6.91																			
23	Wed	0.05	5.81	6.97																			
24	Thu	0.13	3.89	5.32																			
25	Fri	0.04	5.05	7.54																			
26	Sat	0.04	5.08	6.81																			
27	Sun		5.32	7.40																			
28	Mon	0.05	6.11	9.91																			
29	Tue	0.77	8.67	10.03																			
30	Wed	0.01	6.35	7.86																			
31	Thu	0.02	6.32	7.39																			
Totals:		6.90	n/a	n/a	n/a		56.2		56.83														

Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent	Telephone
Jerry P Jackson, Superintendent	219-362-2354

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

Signature of Principal Executive Officer or Authorized Agent	Date
	06/04/2008