

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 1 of 6

Date: Mar-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters		Biotowers				
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Tue	4.1		0.37			0.00	7.59	53	68	14.41	7.49	58	46	13.23	7.55	17	17	9.74	4.6		2.3		0.69	8.3	1.03	
2	Wed	4.0		0.03			0.00	7.54	117	100	16.50	7.46	72	56	15.94	7.52	21	21	11.49	4.6		2.3		0.73	8.3	1.07	
3	Thu	4.2		0.02			0.00	7.56	112	138	16.08	7.42	67	76	17.30	7.32	18	29	12.25	4.6		2.3		0.64	8.3	0.97	
4	Fri	4.4		0.16		2.0	0.00	7.54	122	136	21.21	7.36	76	66	19.63	7.26	16	26	14.02	4.9		2.1		0.60	8.2	0.88	
5	Sat	4.9	4.2	0.08		0.1	0.00	7.59	73	104	11.11	7.38	70	86	13.36	7.27	20	29	10.61	4.8		2.2		0.41	8.1	0.64	
6	Sun	4.4					0.00	7.61	90	64	12.59	7.42	78	60	14.33	7.40	19	23	11.15	4.7		1.7		0.45	7.9	0.78	
7	Mon	4.7		0.05			0.00	7.65	38	85	14.41	7.48	76	66	14.17	7.44	20	26	10.40	4.7		2.1	135	0.45	7.9	0.70	
8	Tue	3.9		0.04			0.00	7.64	103	84	16.74	7.51	81	42	14.99	7.54	23	17	10.81	4.6	40	2.3		0.77	8.3	1.13	60
9	Wed	3.5					0.00	7.61	105	92	21.43	7.50	91	60	20.05	7.40	17	26	13.01	4.7		2.3		0.99	8.3	1.36	
10	Thu	4.2		0.30			0.00	7.59	105	120	17.42	7.49	70	62	16.98	7.48	19	26	13.05	4.7		2.3		0.65	8.3	0.97	
11	Fri	4.7		0.13			0.00	7.62	130	164	16.58	7.41	89	99	16.90	7.41	24	32	12.21	5.0		2.2		0.53	8.4	0.79	
12	Sat	3.3	4.1	0.03			0.00	7.66	115	68	19.34	7.42	91	62	19.80	7.42	21	28	14.99	4.8		1.7		0.96	7.9	1.37	
13	Sun	4.0					0.00	7.51	105	72	15.70	7.37	78	48	15.86	7.31	16	18	11.98	4.8		1.7		0.64	7.9	0.97	
14	Mon	4.0					0.00	7.55	108	102	17.10	7.42	82	68	16.46	7.30	18	24	11.87	4.8		2.1		0.72	7.9	0.98	
15	Tue	4.0					0.00	7.57	121	104	19.22	7.43	80	62	16.10	7.32	17	22	11.45	4.7		2.3		0.76	8.3	1.08	
16	Wed	3.1					0.00	7.54	120	155	22.08	7.35	83	88	22.08	7.36	15	27	16.32	4.7		2.3		1.24	8.3	1.64	
17	Thu	4.2		0.03			0.00	7.55	22	92	15.95	7.40	66	66	19.48	7.34	15	25	15.24	4.7		2.3		0.67	8.3	0.98	
18	Fri	4.3					0.00	7.61	120	122	17.00	7.50	76	72	20.53	7.46	15	24	15.56	4.8		1.9		0.58	7.9	0.85	
19	Sat	5.2	4.1	0.18		0.7	0.00	7.53	104	110	14.18	7.37	78	78	14.53	7.36	21	30	11.43	5.0		2.0		0.35	8.2	0.58	
20	Sun	4.0					0.00	7.48	102	62	15.48	7.34	79	56	16.48	7.38	14	21	11.67	4.8		1.7		0.62	7.9	0.95	
21	Mon	3.4					0.00	7.55	160	122	23.92	7.33	99	66	19.10	7.34	16	23	11.47	4.8		3.0		1.27	7.9	1.32	
22	Tue	3.5		0.04			0.00	7.62	110	118	21.22	7.41	80	68	21.32	7.36	16	25	15.04	4.7		3.2	210	1.26	8.3	1.35	
23	Wed	4.1		0.02			0.00	7.56	90	96	17.62	7.56	94	56	17.82	7.45	14	21	12.62	4.7		2.7		0.81	8.3	1.00	
24	Thu	4.0		0.02			0.00	7.45	100	110	18.73	7.32	63	58	18.32	7.31	11	21	12.24	4.7		3.8		1.12	8.3	1.04	
25	Fri	6.0		0.19			0.00	7.48	103	128	12.32	7.39	85	103	13.58	7.39	21	33	10.75	5.4		3.6		0.48	9.1	0.51	
26	Sat	4.3	4.2	0.06			0.00	7.47	88	70	13.77	7.33	68	66	15.02	7.34	13	21	8.74	4.8		2.9		0.81	7.8	0.83	
27	Sun	2.9					0.00	7.58	135	102	23.22	7.38	103	62	21.67	7.31	12	17	11.49	4.8		3.8		2.02	7.9	1.76	
28	Mon	3.7					0.00	7.63	125	146	21.07	7.51	91	70	19.76	7.39	16	26	13.35	4.8		3.8		1.28	7.9	1.10	
29	Tue	3.5					0.00	7.63	120	124	20.99	7.40	93	66	20.44	7.37	16	23	13.04	4.7		3.8		1.46	8.2	1.38	
30	Wed	4.1		0.12			0.00	7.65	116	117	18.25	7.47	81	74	19.93	7.36	13	27	13.00	4.8		3.7		1.08	8.3	1.03	
31	Thu	4.4	3.8				0.00	7.67	140	160	17.78	7.61	83	76	16.75	7.40	14	23	11.00	4.7		3.7		0.93	8.3	0.89	
AVERAGE		4.1		0.06		0.1	0.00	7.57	105	108	17.53	7.43	80	67	17.48	7.38	17	24	12.32	4.8	1	2.6	11	0.84	8.2	1.03	2
MAXIMUM		6.0	4.2	0.37		2.0	0.00	7.67	160	164	23.92	7.61	103	103	22.08	7.55	24	33	16.32	5.4	40	3.8	210	2.02	9.1	1.76	60
MINIMUM		2.9		0.02		0.0	0.00	7.45	22	62	11.11	7.32	58	42	13.23	7.26	11	17	8.74	4.6	40	1.7	135	0.35	7.8	0.51	60
# OF DATA		31		18		31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	1	31	2		31		1
TOTAL		127		1.87		3	0	235	3252	3335	543	230	2478	2084	542	229	524	750	382	148	40	80	345		253		60

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date: Mar-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Tue	3.8	7.56	5		174		4		128		0.48		16		10.8				
2	Wed	3.7	7.40	4		137		4		134		0.65		22		10.3				
3	Thu	3.8	7.40	4		140		10		342		0.60		21		10.7				
4	Fri	3.8	7.53	4		135		6		219		0.55		20		9.9				
5	Sat	4.4	7.39	4	4	182	148	9	7	351	238	1.30	0.68	54	25	10.5				
6	Sun	3.9	7.51	4		163		6		232		0.48		18		10.7				
7	Mon	4.1	7.52	4		152		7		272		0.52		20		9.9				
8	Tue	3.6	7.60	5		153		3		90		0.45		15		10.4				
9	Wed	3.2	7.57	4		109		6		162		0.36		10		10.7				
10	Thu	3.9	7.52	4		141		5		185		0.62		22		10.6				
11	Fri	4.0	7.49	7		260		12		453		0.66		26		10.6				
12	Sat	3.0	7.44	5	5	139	160	8	7	223	231	0.58	0.52	16	18	10.8				
13	Sun	3.6	7.36	17		561		7		217		0.48		16		10.8				
14	Mon	3.6	7.48	4		136		8		266		0.49		16		10.7				
15	Tue	3.4	7.45	3		106		5		174		0.56		19		10.4				
16	Wed	2.7	7.43	3		81		7		183		0.46		12		10.3				
17	Thu	3.7	7.41	4		140		7		253		0.49		17		10.1				
18	Fri	3.7	7.77	4		124		7		231		0.58		21		10.1				
19	Sat	4.6	7.49	5	6	211	194	11	7	452	254	0.69	0.53	30	19	10.5				
20	Sun	3.5	7.51	3		101		6		211		0.38		13		10.8				
21	Mon	2.8	7.32	4		102		5		128		0.39		11		10.6				
22	Tue	3.0	7.54	3		85		8		220		0.43		13		10.6				
23	Wed	3.7	7.53	3		100		9		310		0.46		16		10.7				
24	Thu	3.5	7.59	3		98		8		278		0.43		14		10.4				
25	Fri	5.4	7.49	5		272		10		504		0.69		35		10.7				
26	Sat	3.7	7.47	3	3	118	125	7	7	232	269	0.39	0.45	14	17	11.1				
27	Sun	2.6	7.65	2		57		6		143		0.52		12		10.8				
28	Mon	3.4	7.75	4		125		10		312		0.55		17		10.1				
29	Tue	3.1	7.60	5		139		6		173		0.32		9		10.2		1.50	17	< 0.01
30	Wed	3.8	7.39	5		157		10		325		0.26		9		10.1		3.00	15	< 0.01
31	Thu	4.0	7.40	9	5	327	149	16	8	591	269	0.28	0.35	10	11	10.1		2.00	12	< 0.01
AVERAGE		3.6	7.50	5		159		7		258		0.52		18		10.5		2.17	15	
MAXIMUM		5.4	7.77	17	6	561	194	16	8	591	269	1.30	0.68	54	25	11.1		3.00	17	
MINIMUM		2.6	7.32	2		57		3		90		0.26		9		9.9		1.50	12	
# OF DATA		31	31	31		31		31		31		31		31		31		3	3	3
TOTAL		113	233	142		4925		229		7993		16		564		325.0		6.50	44	

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 3 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection						Primary & Secondary Settling			Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day	Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)		
1	Tue					20	0	303	6	4	190		
2	Wed					20	0	301	6	4	190		
3	Thu					20	0	300	6	4	189		
4	Fri					21	0	299	6	4	186		
5	Sat					25	0	303	6	4	181		
6	Sun					20	0	301	6	4	191		
7	Mon			7	54	19	0	285	6	4	190		
8	Tue					20	0	316	6	4	189		
9	Wed					20	0	320	6	4	190		
10	Thu					19	0	315	6	4	190		
11	Fri					20	0	319	6	4	192		
12	Sat					20	0	318	6	4	192		
13	Sun					20	0	317	6	4	192		
14	Mon					20	4	313	6	4	192		
15	Tue					20	0	310	6	4	192		
16	Wed					20	0	308	6	4	191		
17	Thu					20	0	309	6	4	194		
18	Fri					20	0	311	6	4	194		
19	Sat					21	0	312	6	4	180		
20	Sun					20	0	313	6	4	195		
21	Mon			27		20	0	314	6	4	194		
22	Tue					20	9	313	6	4	190		
23	Wed					20	0	314	6	5	213		
24	Thu					20	0	313	6	4	199		
25	Fri					24	0	314	6	3	154		
26	Sat					20	0	316	6	4	196		
27	Sun					20	0	314	6	4	194		
28	Mon				27	22	0	314	6	7	246		
29	Tue	50	50			26	15	310	6	4	201		
30	Wed	280	100			26	0	309	6	4	193		
31	Thu	188	72			26	0	312	6	4	187		
AVERAGE		17	7	1	3	21	1	310	6	4	192		
MAXIMUM		280	100	27	54	26	15	320	6	7	246		
MINIMUM		50	50	7	27	19	0	285	6	3	154		
# OF DATA		3	3	2	2	31	31	31	31	31	31		
TOTAL		518	222	34	81	641	27	9615	187	139	5965		

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-05

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard, La Porte IN 46350
Phone # (219)362-2354

Page 4 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester					Digested Sludge Storage Tank			
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)	
1	Tue								96				97	9				23			0.6	
2	Wed								96				96	12				34			0.6	
3	Thu								96				96	14				54			0.6	
4	Fri								96				96	15				55			0.6	
5	Sat								96				96	20				65	0.21		0.5	
6	Sun								96				96	14				54			0.5	
7	Mon		3.42	77.1	6.73	3.67	50.4	6.68	96	1.82	55.5	7.09	96	27	4.88	57.9	7.07	25			0.5	26
8	Tue								96				96	10				24			0.5	
9	Wed								96				96	12				50			0.5	
10	Thu								96				96	14				56			0.5	
11	Fri								96				96	12				53	0.19		0.6	
12	Sat								96				96	14				51			0.6	
13	Sun								96				96	14				54			0.6	
14	Mon		3.25	75.0	6.64	1.46	58.3	6.77	96	1.56	57.4	6.98	96	26	4.65	55.9	6.91	26			0.6	25
15	Tue								96				96	5				14			0.4	
16	Wed								96				96	12				39			0.4	
17	Thu								96				96	12				34			24.6	
18	Fri								96				96	14				37			25.8	
19	Sat								96				96	14				38	0.17		3.3	
20	Sun								96				96	15				42			0.4	
21	Mon		3.41	78.3		1.40	53.2	6.98	96	1.30	55.4	7.16	96	26	4.84	56.5	6.92	2			0.4	28
22	Tue								96				96	17				43			0.5	
23	Wed								96				96	14				50			0.4	
24	Thu								96				96	14				50			0.5	
25	Fri								96				96	17				59	0.14		1.0	
26	Sat								96				96	15				45			1.4	
27	Sun								96				96	8				33	0.18		1.7	
28	Mon		3.80	77.0	6.11	1.36	61.1	6.88	96	1.65	55.6	7.06	96	30	5.10	54.1	6.96	28			1.7	27
29	Tue								96				96	23				45			1.1	
30	Wed								96				96	19				62			0.6	
31	Thu								96				96	20				59			0.7	
AVERAGE			3.47	76.9	6.49	1.97	55.8	6.83	96	1.58	56.0	7.07	96	16	4.87	56.1	6.97	42	0.18		2.3	3
MAXIMUM			3.80	78.3	6.73	3.67	61.1	6.98	96	1.82	57.4	7.16	97	30	5.10	57.9	7.07	65	0.21		25.8	28
MINIMUM			3.25	75.0	6.11	1.36	50.4	6.68	96	1.30	55.4	6.98	96	5	4.65	54.1	6.91	2	0.14		0.4	
# OF DATA			4	4	3	4	4	4	31	4	4	4	31	31	4	4	4	31	5		31	31
TOTAL			14	307	19	8	223	27	2974	6	224	28	2978	488	19	224	28	1305	1		73	105

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Mar-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis

INFLUENT									EFFLUENT						
Method: 24 hour composite									Site: Post Cl2 Tank						
Sample Characteristics		Hg	Cr	Cu	Pb	Ni	Zn	CN-	Hg	Cr	Cu	Pb	Ni	Zn	CN-
Sample Number		CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720	CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720
Sample Type	Permit Condition	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
	Monitored	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
Frequency	Permit Condition	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
	Monitored	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
Parameter Limits	Daily Maximum										0.055				0.016
	Monthly Average										0.024				0.016
1st Date: March 2nd				0.120							0.021				
2nd Date: March 9th			<0.005	0.110	0.003	0.019	0.064	<0.005		<0.005	0.008	0.001	0.007	0.024	<0.005
3rd Date: March 16th				0.089							0.010				
4th Date: March 23rd			<0.005	0.069	0.003	0.010	0.056	<0.005		<0.005	0.024	0.002	<0.002	0.026	0.007
5th Date: March 30th				0.078							0.021				
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	NA	NA	0
Average			<0.003	0.093	0.003	0.015	0.060	<0.003		<0.003	0.017	0.002	0.004	0.025	0.005
Maximum			<0.005	0.120	0.003	0.019	0.064	<0.005		<0.005	0.024	0.002	0.007	0.026	0.007

* We are currently under Agreed Order 2000-9996-W with IDEM to resolve effluent copper concerns.

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.01	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	4.2	4.1	6	5	194	159	8	7	269	258	0.68	0.52	25	18	9.9	7.77		17	15
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 4,598

Overall Percent Removal of Volatile Solids 61.5%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 21,104

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 453

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 59

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 1,061

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 29

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	24%	38%	0%
Secondary Treatment :	79%	64%	30%
Adv. Sec. Treatment :	73%	69%	96%
Overall Treatment :	96%	93%	97%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	4.3	2.0	3.0
Secondary Settling Tank	3.1	1.5	2.2
Final Settling Tank	9.9	4.7	6.9
Total Plant Retention Time	17.3	8.2	12.0

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	755	357	513
Secondary Settling Tank	996	471	677
Final Settling Tank	508	240	345

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	15	7	10
Secondary Settling Tank	12	6	8
Final Settling Tank	12	5	8

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

March 7, 14, 22, 30 - Successful load test of emergency generator and switch gear
 March 21 - North half of secondary Fixed-Bed Trickling back in service for summer operation
 March 28 - South Final Clarifier out of service 8 hours for service

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____

