

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2007
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters		Biotowers				
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Thu	6.2		0.25		6.7	0.00	7.57	90	432	10.80	7.45	184	68	13.60	7.45	29	71	12.55	5.9		3.0		0.44	7.3	0.19	
2	Fri	5.4		0.15			0.00	7.46	68	68	11.40	7.46	62	57	12.10	7.47	29	29	10.50	4.7		2.0		0.25	6.2	0.14	
3	Sat	4.2		0.10			0.00	7.54	103	90	13.60	7.49	74	72	13.60	7.52	29	28	11.10	4.7		1.7		0.56	5.1	0.22	
4	Sun	3.6					0.00	7.55	96	88	16.40	7.50	78	58	19.00	7.74	33	26	16.20	4.7		1.7		0.81	5.0	0.38	
5	Mon	3.5					0.00	7.54	106	168	34.85	7.49	76	54	20.50	7.52	28	24	17.30	4.7		2.1		0.96	5.0	0.44	
6	Tue	3.3		0.05			0.00	7.58	102	98	21.70	7.49	86	82	21.40	7.51	33	32	18.80	4.7		2.3		1.11	4.9	0.48	
7	Wed	2.3		0.03			0.00	7.58	145	117	29.05	7.43	115	56	35.90	7.44	31	20	28.30	4.7		2.3		2.00	5.1	1.16	
8	Thu	2.5					0.00	7.61	125	186	27.35	7.35	116	36	26.10	7.37	31	22	21.25	4.7		2.3		1.85	5.2	1.10	
9	Fri	3.4		0.10			0.00	7.61	170	136	18.50	7.36	120	40	23.80	7.34	30	28	21.30	4.7		2.0		0.98	5.5	0.61	
10	Sat	4.1	3.2	0.02			0.00	7.43	154	78	8.93	7.29	68	28	11.40	7.25	29	25	10.20	4.7		1.8		0.61	5.4	0.32	
11	Sun	3.1					0.00	7.40	97	76	15.80	7.37	68	56	17.65	7.27	27	23	14.20	4.5		1.7		1.03	4.9	0.62	
12	Mon	3.8					0.00	7.64	100	136	14.75	7.68	70	66	13.80	7.79	27	20	11.70	4.7		1.9		0.73	5.2	0.36	
13	Tue	4.0					0.00	7.50	94	88	13.10	7.34	74	32	14.20	7.36	27	27	11.20	4.7		3.4	360	1.01	5.1	0.26	
14	Wed	4.0		0.18			0.00	7.46	92	119	13.80	7.42	70	60	20.20	7.37	20	18	14.20	4.7		3.9		1.14	5.1	0.27	
15	Thu	5.7		0.04		0.7	0.00	7.43	82	112	11.60	7.23	64	94	14.80	7.20	25	29	12.30	6.0		3.8		0.72	6.5	0.14	
16	Fri	3.7					0.00	7.47	95	100	13.90	7.28	83	64	19.00	7.20	21	24	14.45	4.7		3.9		1.36	4.9	0.34	
17	Sat	3.6	4.0				0.00	7.44	106	88	13.40	7.40	82	62	15.30	7.35	22	17	11.10	4.7		3.9		1.43	4.9	0.38	
18	Sun	3.6					0.00	7.50	103	72	13.70	7.39	80	52	17.00	7.40	25	22	12.60	4.7		3.9		1.42	5.0	0.39	
19	Mon	4.3		0.64		0.8	0.00	7.57	130	199	16.10	7.62	90	84	20.90	7.72	28	23	16.00	5.4		3.8		1.15	5.4	0.27	
20	Tue	2.7					0.00	7.54	96	112	19.60	7.40	100	68	24.60	7.38	24	22	15.90	4.7	45	3.8		2.12	4.9	0.81	90
21	Wed	5.5		0.30		3.2	0.00	7.71	85	102	13.00	7.47	72	70	17.30	7.41	22	25	13.70	6.8		3.7		0.89	6.7	0.22	
22	Thu	4.6		0.36		1.4	0.00	7.51	99	104	12.70	7.35	61	90	14.45	7.40	19	27	10.50	6.0		3.6		1.08	6.0	0.30	
23	Fri	6.3		0.33		3.1	0.00	7.57	83	98	15.60	7.34	65	53	10.60	7.35	18	15	8.74	7.1		3.8		0.73	7.1	0.12	
24	Sat	2.9	4.3	0.03			0.00	7.46	110	96	17.40	7.35	97	24	17.10	7.33	19	9	10.20	4.8		3.2		1.76	5.0	0.73	
25	Sun	3.6					0.00	7.43	100	68	14.10	7.34	75	36	14.90	7.35	17	17	10.00	4.8		3.7		1.34	5.0	0.36	
26	Mon	3.8					0.00	7.42	105	89	20.50	7.32	95	38	22.40	7.32	18	15	13.50	4.7		3.7		1.24	4.9	0.31	
27	Tue	3.2					0.00	7.45	170	118	16.50	7.34	108	52	20.40	7.31	16	16	11.50	4.7		3.7		1.65	4.9	0.52	
28	Wed	5.2		0.23		2.4	0.00	7.45	107	112	12.60	7.38	76	80	15.10	7.34	19	21	11.50	6.4		3.5		0.90	6.6	0.26	
29	Thu	3.5					0.00	7.45	107	112	12.60	7.38	76	80	15.10	7.34	19	21	11.50	5.6		3.8		1.68	5.1	0.45	
30	Fri	3.3					0.00	7.52	97	104	21.90	7.33	82	66	29.00	7.22	15	18	15.85	4.7		3.3		1.42	5.1	0.52	
31	Sat	4.2	3.8	0.32			0.00	7.53	113	144	17.55	7.35	77	69	33.50	7.30	15	17	20.50	6.0		3.8		1.34	5.5	0.31	
AVERAGE		4.0		0.10		0.6	0.00	7.51	107	120	16.54	7.40	85	60	18.86	7.40	24	24	14.15	5.1	1	3.1	12	1.15	5.4	0.42	3
MAXIMUM		6.3	4.3	0.64		6.7	0.00	7.71	170	432	34.85	7.68	184	94	35.90	7.79	33	71	28.30	7.1	45	3.9	360	2.12	7.3	1.16	90
MINIMUM		2.3		0.02		0.0	0.00	7.40	68	68	8.93	7.23	61	24	10.60	7.20	15	9	8.74	4.5	45	1.7	360	0.25	4.9	0.12	90
# OF DATA		31		16		31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	1	31	1		31		1
TOTAL		123		3.13		18	0	233	3329	3710	513	229	2642	1847	585	229	740	730	439	159	45	95	360		168		90

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date : Mar-2007

LaPorte Wastewater Treatment Plant

Permit # IN0025577

2101 Boyd Boulevard

Expires 10-31-2009

LaPorte IN, 46350

Certified Operator : Jerry P Jackson

Phone # (219)362-2354

Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Thu	5.9	7.50	12		626		19		949		2.96		152		9.9				
2	Fri	5.3	7.33	7		324		5		225		1.03		46		10.5				
3	Sat	4.2	7.57	6		205		5		174		1.07		37		10.8				
4	Sun	3.6	7.93	6		189		6		172		1.33		40		10.8				
5	Mon	3.5	7.52	6		172		1		29		1.69		49		10.0				
6	Tue	3.3	7.50	7		187		8		209		1.85		52		10.5				
7	Wed	2.4	7.55	6		113		2		29		1.74		34		9.9				
8	Thu	2.5	7.51	7		151		3		57		2.80		58		9.7				
9	Fri	3.4	7.45	6		179		6		156		4.37		124		9.5				
10	Sat	4.1	7.43	9	7	288	183	5	4	169	117	2.01	2.26	68	61	9.6				
11	Sun	3.1	7.32	6		158		8		191		1.12		29		10.4				
12	Mon	3.8	8.11	7		210		7		223		1.01		32		9.8				
13	Tue	3.9	7.42	10		318		16		528		0.71		24		9.6				
14	Wed	3.9	7.49	7		231		8		251		1.24		41		9.6				
15	Thu	5.5	7.46	15		732		22		1034		1.75		83		10.5				
16	Fri	3.6	7.13	6		168		6		183		0.94		29		10.7				
17	Sat	3.6	7.44	6	8	175	285	6	10	163	368	0.97	1.11	29	38	11.1				
18	Sun	3.6	7.41	6		184		6		171		0.77		23		10.7				
19	Mon	4.3	7.82	8		267		5		178		1.09		39		10.3				
20	Tue	2.7	7.47	12		265		19		425		1.22		28		9.8				
21	Wed	5.4	7.41	8		360		9		393		1.38		64		10.1				
22	Thu	4.6	7.50	12		461		23		893		0.82		31		9.4				
23	Fri	6.1	7.50	10		540		12		603		0.73		38		9.8				
24	Sat	3.0	7.48	13	10	307	341	22	13	520	455	0.52	0.93	13	34	9.7				
25	Sun	3.6	7.48	5		161		7		197		0.40		12		9.2				
26	Mon	3.7	7.40	6		196		7		221		0.48		15		8.7		0.71		< 0.01
27	Tue	3.1	7.39	5		123		4		114		0.44		12		8.8		1.88		< 0.01
28	Wed	5.1	7.43	12		521		14		608		0.70		30		10.3		2.41		< 0.01
29	Thu	3.5	7.43	12		351		14		410		0.70		20		10.3		2.41		< 0.01
30	Fri	3.2	7.42	9		247		19		520		0.29		8		10.4		1.89		< 0.01
31	Sat	4.1	7.33	4	8	129	247	5	10	175	320	0.84	0.55	29	18	9.6		2.04	4	< 0.01
AVERAGE		3.9	7.49	8		275		9		328		1.26		42		10.0		1.89	4	
MAXIMUM		6.1	8.11	15	10	732	341	23	13	1034	455	4.37	2.26	152	61	11.1		2.41	4	
MINIMUM		2.4	7.13	4		113		1		29		0.29		8		8.7		0.71	4	
# OF DATA		31	31	31		31		31		31		31		31		31		6	1	6
TOTAL		122	232	249		8538		292		10169		39		1289		310.0		11.34	4	

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2007

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection						Primary & Secondary Settling			Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day	Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)		
1	Thu					23	0	317	6	2	63		
2	Fri					20	0	319	6	2	90		
3	Sat					22	0	308	6	2	90		
4	Sun					26	0	317	6	2	91		
5	Mon					23	0	317	6	2	90		
6	Tue			27	27	20	0	318	6	2	89		
7	Wed					20	0	316	6	2	89		
8	Thu					20	0	315	6	2	90		
9	Fri					20	0	314	6	2	88		
10	Sat					20	0	313	6	2	88		
11	Sun					19	0	297	6	2	88		
12	Mon					20	0	306	6	2	87		
13	Tue			20		20	0	303	5	7	184		
14	Wed					20	13	299	6	7	188		
15	Thu					22	0	297	6	2	67		
16	Fri					20	3	294	6	2	86		
17	Sat					20	0	293	6	2	86		
18	Sun					20	0	291	6	2	85		
19	Mon			20	27	21	0	294	6	2	85		
20	Tue					20	0	304	6	2	84		
21	Wed					22	0	310	6	2	71		
22	Thu					21	0	310	6	2	57		
23	Fri			20	27	22	9	309	6	2	84		
24	Sat					20	0	305	6	2	83		
25	Sun					20	0	299	6	2	82		
26	Mon	40	40			20	0	294	6	2	84		
27	Tue	135	80			20	0	292	6	2	78		
28	Wed	245	145			21	0	293	6	2	74		
29	Thu	140	30			21	0	289	6	2	88		
30	Fri	140	45	20	27	21	11	302	6	2	81		
31	Sat	200	80			21	0	302	6	2	81		
AVERAGE		29	14	3	3	21	1	304	6	2	89		
MAXIMUM		245	145	27	27	26	13	319	6	7	188		
MINIMUM		40	30	20	27	19	0	289	5	2	57		
# OF DATA		6	6	5	4	31	31	31	31	31	31		
TOTAL		900	420	108	108	647	37	9438	185	76	2771		

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2007

LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester					Digested Sludge Storage Tank			
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)	
1	Thu								96				95	12				39			0.1	
2	Fri								96				95	7				34			0.0	
3	Sat								96				95	11				37	0.03			
4	Sun								96				95	19				60	0.17			
5	Mon		3.42	73.8	6.45	3.56	55.8	6.93	96	3.57	65.8	7.12	95	30	4.37	57.1	6.91	20			0.0	30
6	Tue								96				95	9				12			0.0	
7	Wed								96				95	14				41				
8	Thu								96				95	11				40			0.0	
9	Fri								96				95	12				44	0.09		0.0	
10	Sat								96				95	6				20			0.0	
11	Sun								96				95	15				47			0.0	
12	Mon		2.98	82.5	6.37	3.01	55.9	7.27	96	3.12	63.6	7.16	95	22	4.50	62.6	7.17	1			0.0	27
13	Tue								96				95	2				0			0.0	
14	Wed								96				95	30				64			0.1	
15	Thu								96				95	9				34			0.1	
16	Fri								96				95	16				51			0.0	
17	Sat								96				95	9				36	0.08		0.0	
18	Sun								96				95	9				40	0.27		25.5	
19	Mon		1.73	80.6	6.58	1.93	61.2	6.85	96	2.08	62.5	7.03	95	13	5.01	58.1	7.11	43	0.07		22.7	
20	Tue								96				95	34				15			10.2	41
21	Wed								96				95	4				0			0.9	
22	Thu								96				95	4				0			45.5	
23	Fri								96				95	20				49			23.5	
24	Sat								96				95	13				37			0.5	
25	Sun								96				95	11				33			0.4	
26	Mon		3.60	77.2	6.24	2.16	58.9	7.05	96	1.92	60.5	7.02	95	18	4.56	58.2	7.17	4			0.0	22
27	Tue								96				95	3				0			0.0	
28	Wed								96				95	15				50			0.0	
29	Thu								96				95	8				35			0.0	
30	Fri								96				95	26				66			13.6	
31	Sat								96				95	10				33			18.3	
AVERAGE			2.93	78.5	6.41	2.67	58.0	7.03	96	2.67	63.1	7.08	95	14	4.61	59.0	7.12	32	0.12		5.2	4
MAXIMUM			3.60	82.5	6.58	3.56	61.2	7.27	96	3.57	65.8	7.16	95	34	5.01	62.6	7.17	66	0.27		45.5	41
MINIMUM			1.73	73.8	6.24	1.93	55.8	6.85	96	1.92	60.5	7.02	95	2	4.37	57.1	6.91	0	0.03			
# OF DATA			4	4	4	4	4	4	31	4	4	4	31	31	4	4	4	31	6		31	31
TOTAL			12	314	26	11	232	28	2967	11	252	28	2947	421	18	236	738	986	1		162	121

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Mar-2007

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l except mercury (Hg) which is given in ng/l.

INFLUENT									EFFLUENT								
Method: 24 hour composite (except for Hg, which is grab)									Site: Post Cl2 Tank								
Sample Characteristics		Hg	Cr	Cu	Pb		Ni	Zn	CN-	Hg	Cr	Cu	Pb		Ni	Zn	CN-
Sample Number		CO71900	CO1032	CO1042	CO1051		CO1074	CO1092	CO0720	CO71900	CO1032	CO1042	CO1051		CO1074	CO1092	CO0720
Sample Type	Permit Condition	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour
	Monitored	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour
Frequency	Permit Condition	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days
	Monitored	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days
Parameter Limits	Daily Maximum											0.055					0.016
	Monthly Average											0.024					0.016
1st Date:	March 7th, 2007		<0.005	0.120	0.005		0.038	0.097	0.007		<0.005	0.016	<0.005		0.012	0.036	<0.005
2nd Date:	March 14th, 2007			0.064								0.017					
3rd Date:	March 21st, 2007		0.005	0.090	0.006		0.008	0.071	<0.005			0.013					<0.005
4th Date:	March 28th, 2007			0.066								0.030					
5th Date:																	
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0	NA	NA	NA	NA	0
Average			0.004	0.085	0.006		0.023	0.084	0.005		<0.003	0.019	<0.003		0.012	0.036	<0.003
Maximum			0.005	0.120	0.006		0.038	0.097	0.007		<0.005	0.030	<0.005		0.012	0.036	<0.005

* We are currently under Agreed Order 2000-9996-W with IDEM to resolve effluent copper concerns.

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	4.3	4.0	10	8	341	275	13	9	455	328	2.26	1.26	61	42	8.7	8.11		4	4
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2007
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 4,008

Overall Percent Removal of Volatile Solids 60.6%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 20,899

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 485

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 71

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 706

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 29

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 5

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	21%	50%	-14%
Secondary Treatment :	72%	60%	25%
Adv. Sec. Treatment :	66%	60%	91%
Overall Treatment :	93%	92%	92%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	5.2	1.9	3.1
Secondary Settling Tank	3.8	1.4	2.3
Final Settling Tank	12.0	4.5	7.1
Chlorine Contact Tank	0.83	0.31	0.49
Total Plant Retention Time	21.0	7.8	12.4

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	786	293	496
Secondary Settling Tank	1038	387	655
Final Settling Tank	529	197	334

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	15	6	10
Secondary Settling Tank	12	5	8
Final Settling Tank	12	4	8

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

March 13, 2007 - Started north half of Fixed-Bed Trickling Filter for summer operation

March 7, 21, 28 - Successful test of emergency power system

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____



**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
CSO DISCHARGE MONITORING REPORT (CSO DMR)**

STATE FORM 50546 (9-01)

City: La Porte	Page:	1 of	1
Facility: La Porte Wastewater Treatment Facility	Permit Number:	IN0025577	
Monitoring Period: (MM/DD/YY to MM/DD/YY)	03/01/2007	03/31/2007	Check box if no CSO discharge occurred for the month: <input checked="" type="checkbox"/>

Design Peak Inf. Flow(MGD)					Measured/Metered (M) or Estimated (E) must be specified.(Please attach methods used.)																				
9.7					CSO Outfall No. 002							CSO Outfall No.							CSO Outfall No.						
Day of Month	Day of Week	Precip. in Inches	Avg Infl. Flow Rate (MGD)	Peak Infl. Flow Rate (MGD)	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E			
1	Thu	0.25	6.15	10.07																					
2	Fri	0.15	5.40	6.48																					
3	Sat	0.1	4.16	5.15																					
4	Sun		3.59	4.70																					
5	Mon		3.50	4.34																					
6	Tue	0.05	3.34	4.54																					
7	Wed	0.03	2.34	3.31																					
8	Thu		2.47	3.99																					
9	Fri	0.1	3.41	6.52																					
10	Sat	0.02	4.06	6.72																					
11	Sun		3.06	4.74																					
12	Mon		3.82	4.90																					
13	Tue		4.02	5.12																					
14	Wed	0.18	4.01	5.32																					
15	Thu	0.04	5.70	10.02																					
16	Fri		3.66	4.38																					
17	Sat		3.55	4.40																					
18	Sun		3.57	4.57																					
19	Mon	0.64	4.28	9.84																					
20	Tue		2.72	3.78																					
21	Wed	0.3	5.54	10.14																					
22	Thu	0.36	4.60	10.03																					
23	Fri	0.33	6.29	10.10																					
24	Sat	0.03	2.90	5.24																					
25	Sun		3.63	5.07																					
26	Mon		3.78	5.28																					
27	Tue		3.20	6.26																					
28	Wed	0.23	5.21	10.04																					
29	Thu		3.51	5.28																					
30	Fri		3.32	5.57																					
31	Sat	0.32	4.19	9.61																					
Totals:		3.13	n/a	n/a	n/a		0.0		0.00																

Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent	Telephone
Jerry P Jackson, Superintendent	219-362-2354

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

Signature of Principal Executive Officer or Authorized Agent	Date
	09/16/2007