

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2008
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters	Biotowers					
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Sat	5.1					0.00	7.51	93	120	16.10	7.51	82	60	17.30	7.56	26	29	15.20	5.2		2.4		0.49	6.1	0.20	
2	Sun	7.0				8.4	0.00	7.39	87	126	9.41	7.35	50	76	11.80	7.36	27	36	11.10	6.1		2.9		0.29	7.7	0.09	
3	Mon	9.5		0.32		15.4	2.96	7.36	42	119	4.42	7.24	22	86	8.32	7.25	12	48	8.04	7.5		3.9		0.20	9.7	0.02	
4	Tue	7.2		0.03			0.26	7.41	43	50	8.20	7.41	48	50	9.76	7.47	25	27	9.75	7.5		3.9		0.59	7.6	0.05	
5	Wed	7.2					0.00	7.40	57	60	9.48	7.38	50	46	10.15	7.32	22	23	9.37	7.5		3.9		0.58	7.5	0.03	
6	Thu	7.2		0.01			0.00	7.37	33	70	11.60	7.33	42	54	11.80	7.34	22	32	11.25	6.9		3.9		0.51	7.4	0.04	
7	Fri	6.9					0.00	7.47	48	52	9.43	7.43	37	56	11.30	7.50	20	28	10.40	6.6		3.6		0.49	7.1	0.04	
8	Sat	6.7	7.4				0.00	7.36	68	62	9.82	7.35	56	42	10.10	7.51	27	27	9.24	5.3		3.5		0.32	7.0	0.05	
9	Sun	6.4					0.00	7.42	62	58	9.28	7.34	50	42	10.10	7.43	16	26	9.58	5.8		3.2		0.41	6.6	0.03	
10	Mon	4.9					0.00	7.48	101	111	11.90	7.35	63	68	11.00	7.35	22	26	9.06	5.0		2.7		0.58	5.8	0.20	
11	Tue	5.1					0.00	7.50	99	118	10.90	7.41	75	118	11.45	7.55	22	23	11.20	5.3		2.8		0.59	6.2	0.20	
12	Wed	6.0					0.00	7.48	78	137	9.44	7.41	58	64	9.57	7.44	19	28	8.60	5.6		2.9		0.41	6.4	0.07	
13	Thu	5.9					0.00	7.49	67	142	10.10	7.40	53	78	10.90	7.41	20	25	9.63	5.5		3.0		0.45	6.4	0.09	
14	Fri	5.6					0.00	7.45	70	74	10.70	7.37	61	52	11.80	7.31	18	16	10.10	5.0		2.4		0.32	6.1	0.08	
15	Sat	5.6	5.6				0.00	7.46	77	58	10.20	7.39	64	46	10.00	7.49	19	18	8.57	5.3		2.3		0.37	6.2	0.11	
16	Sun	5.1					0.00	7.49	87	86	11.60	7.44	52	44	12.75	7.49	18	21	10.60	4.8		1.8		0.30	5.9	0.18	
17	Mon	5.6		0.18			0.00	7.63	100	187	10.30	7.89	72	84	10.65	7.43	22	33	8.51	5.2		2.5		0.37	6.3	0.14	
18	Tue	6.5		0.24		0.3	0.00	7.48	68	96	9.30	7.44	52	70	9.70	7.49	24	30	7.14	5.9		3.1		0.39	6.8	0.05	
19	Wed	5.8		0.03			0.00	7.45	69	58	11.20	7.47	58	46	10.30	7.50	19	16	8.11	4.7		2.8		0.30	6.2	0.07	
20	Thu	5.2					0.00	7.51	73	86	11.50	7.42	56	38		7.39	19	17	8.93	4.7		2.4		0.36	6.1	0.16	
21	Fri	5.4		0.02			0.00	7.57	78	86	10.80	7.44	58	57	16.75	7.60	18	23	13.15	4.7		2.3		0.30	6.2	0.14	
22	Sat	5.4	5.6	0.03			0.00	7.50	78	88	11.40	7.48	64	64	12.90	7.53	22	26	10.20	5.0		2.3		0.34	6.3	0.16	
23	Sun	4.9					0.00	7.46	82	54	11.30	7.38	67	40	12.00	7.36	18	23	9.79	4.7		1.8		0.35	5.9	0.22	
24	Mon	5.1					0.00	7.52	110	104	11.00	7.39	78	78	12.50	7.43	19	27	9.71	4.7		2.2		0.36	6.1	0.21	
25	Tue	5.1					0.00	7.59	78	82	11.30	7.54	61	60	10.80	7.67	18	22	8.11	4.7		2.4		0.39	5.6	0.09	
26	Wed	4.9					0.00	7.47	69	80	12.30	7.42	65	60	11.60	7.38	16	18	8.83	4.7		2.3		0.43	5.5	0.12	
27	Thu	6.7		0.47		5.2	0.00	7.45	75	140	9.17	7.42	65	102	10.50	7.44	23	35	8.94	5.7		3.1		0.31	7.2	0.07	
28	Fri	7.8				1.1	0.00	7.52	40	62	7.60	7.44	43	64	10.00	7.45	16	40	8.35	7.3		4.0		0.45	7.9	0.02	
29	Sat	6.4	5.8				0.00	7.49	42	46	8.41	7.35	40	44	8.86	7.35	15	18	6.80	5.0		3.2		0.28	6.6	0.03	
30	Sun	5.6		0.03			0.00	7.38	63	96	10.10	7.37	53	50	11.80	7.36	16	20	8.86	4.9		2.4		0.32	5.9	0.07	
31	Mon	6.8		0.47		5.4	0.00	7.43	70	121	7.72	7.35	52	74	7.55	7.36	17	26	5.77	5.8		2.8		0.27	7.0	0.04	
AVERAGE		6.1		0.06		1.2	0.10	7.47	71	91	10.19	7.42	56	62	11.13	7.44	20	26	9.45	5.6		2.9		0.39	6.6	0.10	
MAXIMUM		9.5	7.4	0.47		15.4	2.96	7.63	110	187	16.10	7.89	82	118	17.30	7.67	27	48	15.20	7.5		4.0		0.59	9.7	0.22	
MINIMUM		4.9		0.01		0.0	0.00	7.36	33	46	4.42	7.24	22	38	7.55	7.25	12	16	5.77	4.7		1.8		0.20	5.5	0.02	
# OF DATA		31		11		31	31	31	31	31	31	31	31	31	30	31	31	31	31	31		31			31		
TOTAL		188		1.83		36	3	231	2208	2829	316	230	1746	1913	334	231	609	806	293	173		89			205		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date : Mar-2008

LaPorte Wastewater Treatment Plant

Permit # IN0025577

2101 Boyd Boulevard

Expires 10-31-2009

LaPorte IN, 46350

Certified Operator : Jerry P Jackson

Phone # (219)362-2354

Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Sat	4.5	7.58	7		286		7		299		2.25		96		10.1				
2	Sun	6.2	7.53	10		610		15		850		1.96		115		10.2				
3	Mon	8.5	7.17	9		737		16		1268		1.52		120		11.0				
4	Tue	6.5	7.36	8		475		7		421		1.76		106		10.7				
5	Wed	6.4	7.48	7		416		8		482		1.38		83		10.8				
6	Thu	6.4	7.42	7		430		11		656		1.25		75		10.7				
7	Fri	6.1	7.43	6		349		8		457		1.45		83		10.3				
8	Sat	6.0	7.52	8	8	428	492	7	10	389	646	1.25	1.51	69	93	10.4				
9	Sun	5.7	7.58	8		421		8		427		1.25		67		10.5				
10	Mon	4.4	7.56	6		247		7		284		0.95		38		10.1				
11	Tue	4.5	7.62	7		296		9		386		1.37		59		9.3				
12	Wed	5.4	7.60	6		321		10		502		1.05		53		10.0				
13	Thu	5.2	7.54	6		290		8		393		1.10		54		9.7				
14	Fri	5.0	7.53	7		346		3		140		1.02		48		9.6				
15	Sat	4.9	7.53	6	7	260	312	4	7	186	331	0.78	1.07	36	51	9.7				
16	Sun	4.5	7.58	4		181		5		211		0.91		38		9.4				
17	Mon	4.9	7.52	6		266		8		373		0.74		35		9.8				
18	Tue	5.8	7.64	6		341		11		569		0.71		38		9.7				
19	Wed	5.1	7.52	5		217		3		145		0.54		26		9.8				
20	Thu	4.6	7.50	4		183		2		65		0.55		24		9.8				
21	Fri	4.8	7.55	5		207		6		271		1.70		77		9.4				
22	Sat	4.8	7.51	5	5	239	234	7	6	316	278	1.31	0.92	59	42	9.9				
23	Sun	4.3	7.50	5		194		6		243		0.65		26		9.8				
24	Mon	4.6	7.51	5		220		6		254		0.65		27		9.7				
25	Tue	4.3	7.65	4		175		9		383		0.46		20		9.7				
26	Wed	4.3	7.73	4		181		8		329		0.42		17		9.9				
27	Thu	5.9	7.51	6		358		7		392		0.84		47		9.6		1.85		< 0.01
28	Fri	6.8	7.21	7		448		7		454		0.84		54		10.6		2.49		< 0.01
29	Sat	5.6	7.25	5	5	257	262	6	7	321	339	0.41	0.61	22	31	10.6		2.19		< 0.01
30	Sun	4.9	7.34	4		199		10		463		0.35		16		10.2		2.11		< 0.01
31	Mon	5.9	7.34	6		316		6		339		0.32		18		9.7		1.91	1	< 0.01
AVERAGE		5.4	7.49	6		319		8		396		1.02		53		10.0		2.11	1	
MAXIMUM		8.5	7.73	10	8	737	492	16	10	1268	646	2.25	1.51	120	93	11.0		2.49	1	
MINIMUM		4.3	7.17	4		175		2		65		0.32		16		9.3		1.85	1	
# OF DATA		31	31	31		31		31		31		31		31		31		5	1	5
TOTAL		167	232	190		9892		234		12265		32		1647		310.7		10.55	1	

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2008

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection						Primary & Secondary Settling			Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day	Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)		
1	Sat					20	0	280	6	2	77		
2	Sun					35	0	273	6	1	60		
3	Mon					45	6	272	6	0	17		
4	Tue				27	14	0	307	6	2	89		
5	Wed			20		20	0	286	6	1	61		
6	Thu					20	0	286	6	2	61		
7	Fri					22	0	285	6	2	84		
8	Sat					20	0	283	6	2	86		
9	Sun					19	0	270	6	2	81		
10	Mon			14		20	0	274	6	2	84		
11	Tue					20	0	271	6	2	92		
12	Wed			27	27	20	0	265	6	2	68		
13	Thu					20	0	261	6	2	74		
14	Fri					20	0	260	6	2	85		
15	Sat					20	0	259	6	2	83		
16	Sun					20	0	257	6	2	82		
17	Mon				14	20	0	252	6	2	82		
18	Tue					23	0	251	6	1	48		
19	Wed					20	0	248	6	2	82		
20	Thu			27		20	0	247	6	2	83		
21	Fri					20	0	257	6	2	85		
22	Sat					20	0	270	6	2	83		
23	Sun					20	0	308	6	2	83		
24	Mon				27	20	0	313	6	2	83		
25	Tue					20	6	309	6	2	83		
26	Wed					20	0	297	6	7	175		
27	Thu					31	0	291	6	8	173		
28	Fri	120	20			24	0	276	6	1	70		
29	Sat	200	120			20	0	289	6	2	91		
30	Sun	180	140			20	0	284	6	2	90		
31	Mon	26	180			31	0	281	6	2	63		
AVERAGE		17	15	3	3	22	0	276	6	2	82		
MAXIMUM		200	180	27	27	45	6	313	6	8	175		
MINIMUM		26	20	14	14	14	0	247	6	0	17		
# OF DATA		4	4	4	4	31	31	31	31	31	31		
TOTAL		526	460	88	95	684	13	8560	186	72	2557		

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2008

LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester					Digested Sludge Storage Tank		
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)
1	Sat								96				96					0	0.07		
2	Sun								96				96	23				43			
3	Mon		1.75	77.0	6.45	1.55	55.1	6.63	96	0.91	53.7	7.01	96	38	5.83	53.7	7.05	91			
4	Tue								96				96	8				21	0.22		
5	Wed								96				96	14				36			
6	Thu								96				96	13				28			
7	Fri								96				96	15				39			
8	Sat								96				96	9				23	0.05		
9	Sun								96				96	17				36	0.17		
10	Mon		3.05	72.8	6.51	1.63	58.2	6.76	96	4.63	54.7	6.94	96	34	6.04	53.4	6.94	7			45
11	Tue								96				96	1				0			
12	Wed								96				96					0			
13	Thu								96				96	19				15			
14	Fri								96				96	9				24			
15	Sat								96				96	7				15	0.12		
16	Sun								96				96	20				47			
17	Mon		2.06	77.1	6.03	1.43	57.9	6.66	96	2.44	56.7	7.13	96	32	7.63	53.4	6.94	10			46
18	Tue								96				96	5				11			
19	Wed								96				96	3				1			
20	Thu								96				96	7				10			
21	Fri								96				96	10				38			
22	Sat								96				96	14				46	0.16		
23	Sun								96				96	12				43	0.13		
24	Mon		3.78	72.2	6.94	1.71	56.3	6.84	96	2.19	57.0	7.09	96	33	6.83	53.9	7.16	20			39
25	Tue								96				96	7				3			
26	Wed								96				96	5				3			
27	Thu								96				96	18				58			
28	Fri								96				96	35				82			
29	Sat								96				96	12				34			
30	Sun								96				96	12				33			
31	Mon		4.07	72.6	5.92	3.82	53.5	6.85	96	3.45	55.7	7.13	96	35	7.52	53.0	6.98	11			41
AVERAGE			2.94	74.3	6.37	2.03	56.2	6.75	96	2.72	55.6	7.06	96	15	6.77	53.5	7.01	27	0.13		6
MAXIMUM			4.07	77.1	6.94	3.82	58.2	6.85	96	4.63	57.0	7.13	96	38	7.63	53.9	7.16	91	0.22		46
MINIMUM			1.75	72.2	5.92	1.43	53.5	6.63	96	0.91	53.7	6.94	96		5.83	53.0	6.94	0	0.05		
# OF DATA			5	5	5	5	5	5	31	5	5	5	31	31	5	5	5	31	7		31
TOTAL			15	372	32	10	281	34	2976	14	278	35	2975	468	34	267	35	830	1		173

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Mar-2008

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l except mercury (Hg) which is given in ng/l.

INFLUENT									EFFLUENT								
Method: 24 hour composite (except for Hg, which is grab)									Site: Post Cl2 Tank								
Sample Characteristics		Hg	Cr	Cu	Pb		Ni	Zn	CN-	Hg	Cr	Cu	Pb		Ni	Zn	CN-
Sample Number		CO71900	CO1032	CO1042	CO1051		CO1074	CO1092	CO0720	CO71900	CO1032	CO1042	CO1051		CO1074	CO1092	CO0720
Sample Type	Permit Condition	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour
	Monitored	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour		24 Hour	24 Hour	24 Hour
Frequency	Permit Condition	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days
	Monitored	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual		4 X Annual	4 X Annual	2-31 Days
Parameter Limits	Daily Maximum											0.055					0.016
	Monthly Average											0.024					0.016
1st Date :	March 5th		<0.005	0.026	<0.005		<0.005	0.046	<0.005		<0.005	0.011	<0.005		<0.005	0.022	<0.005
2nd Date :	March 12th			0.036								0.016					
3rd Date :	March 17th		0.008	0.065	0.010		0.007	0.110	<0.005			0.012					<0.005
4th Date :	March 26th			0.044								0.014					
5th Date :																	
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	*See Note	0	NA	NA	NA	0
Average			0.005	0.043	0.006		0.005	0.078	<0.003		<0.003	0.013	<0.003		<0.003	0.022	<0.003
Maximum			0.008	0.065	0.010		0.007	0.110	<0.005		<0.005	0.016	<0.005		<0.005	0.022	<0.005

* We are currently under Agreed Order 2000-9996-W with IDEM to resolve effluent copper concerns.

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	7.4	6.1	8	6	492	319	10	8	646	396	1.51	1.02	93	53	9.3	7.73		1	1
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-2008
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 4,027

Overall Percent Removal of Volatile Solids 60.3%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 21,228

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 527

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 66

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 861

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 31

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 6

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	21%	32%	-9%
Secondary Treatment :	65%	58%	15%
Adv. Sec. Treatment :	69%	71%	89%
Overall Treatment :	91%	92%	90%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	2.5	1.3	2.0
Secondary Settling Tank	1.8	0.9	1.5
Final Settling Tank	5.8	3.0	4.6
Chlorine Contact Tank	0.40	0.20	0.32
Total Plant Retention Time	10.2	5.2	8.1

Surface Flow Rate	Maximum	Minimum	Average
Gallons per sq ft per Day			
Primary Settling Tank	1188	607	760
Secondary Settling Tank	1568	801	1003
Final Settling Tank	799	408	511

Weir OverFlow Rate	Maximum	Minimum	Average
1000 Gal per ft per Day			
Primary Settling Tank	23	12	15
Secondary Settling Tank	19	10	12
Final Settling Tank	18	9	12

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

3/3/2008 - CSO overflow was the result of a rainfall-induced snow melt

3/5/2008 - Successful test of emergency power

3/14/2008 - North half of fix-bed trickling filter put back in service after winter

3/27/2008 - Disinfection system briefly tested, no use of chemical recorded

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____



**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
CSO DISCHARGE MONITORING REPORT (CSO DMR)**

STATE FORM 50546 (9-01)

City: La Porte	Page: 1 of 1
Facility: La Porte Wastewater Treatment Facility	Permit Number: IN0025577
Monitoring Period: (MM/DD/YY to MM/DD/YY) 03/01/2008 03/31/2008	Check box if no CSO discharge occurred for the month: <input type="checkbox"/>

Design Peak Inf. Flow(MGD) **9.7** Measured/Metered (M) or Estimated (E) must be specified.(Please attach methods used.)

Day of Month	Day of Week	Precip. in Inches	Avg Infl. Flow Rate (MGD)	Peak Infl. Flow Rate (MGD)	CSO Outfall No. 002						CSO Outfall No.						CSO Outfall No.					
					Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E
1	Sat		5.12	7.54																		
2	Sun		7.03	10.12																		
3	Mon	0.32	9.50	10.12	10:50		13.2	M		2.96	M											
4	Tue	0.03	7.20	7.94	0:00		10.6	M		0.26	M											
5	Wed		7.22	8.98																		
6	Thu	0.01	7.15	8.56																		
7	Fri		6.85	7.71																		
8	Sat		6.67	7.46																		
9	Sun		6.40	7.68																		
10	Mon		4.86	6.88																		
11	Tue		5.14	7.84																		
12	Wed		6.02	7.90																		
13	Thu		5.89	8.43																		
14	Fri		5.60	6.78																		
15	Sat		5.56	7.45																		
16	Sun		5.06	5.93																		
17	Mon	0.18	5.59	8.42																		
18	Tue	0.24	6.49	9.71																		
19	Wed	0.03	5.78	7.24																		
20	Thu		5.23	6.27																		
21	Fri	0.02	5.41	7.59																		
22	Sat	0.03	5.41	7.67																		
23	Sun		4.85	5.68																		
24	Mon		5.07	5.93																		
25	Tue		5.10	5.78																		
26	Wed		4.93	5.52																		
27	Thu	0.47	6.71	10.11																		
28	Fri		7.78	10.05																		
29	Sat		6.41	7.37																		
30	Sun	0.03	5.56	7.47																		
31	Mon	0.47	6.77	10.00																		
Totals:		1.83	n/a	n/a	n/a		23.8			3.22												

Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent Jerry P Jackson, Superintendent	Telephone 219-362-2354
--	----------------------------------

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

Signature of Principal Executive Officer or Authorized Agent	Date 06/04/2008
--	---------------------------