

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters		Biotowers				
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Mon	4.1					0.00	7.41	103	148	14.30	7.42	63	92	15.10	7.33	18	23	10.85	4.6		2.2		0.64	5.7	0.37	
2	Tue	3.6					0.00	7.48	92	76	14.15	7.33	72	56	13.70	7.32	16	14	10.00	4.6		2.3		0.89	5.4	0.50	
3	Wed	3.6					0.00	7.43	97	127	15.85	7.34	78	76	18.50	7.40	15	25	12.50	4.6		2.3		0.88	5.4	0.49	
4	Thu	3.9					0.00	7.47	125	116	25.30	7.35	88	88	17.90	7.37	17	18	14.90	4.6		2.3		0.77	5.5	0.44	
5	Fri	3.6					0.00	7.50	107	96	13.80	7.36	77	86	16.10	7.28	17	23	12.30	4.6		1.9		0.81	5.4	0.51	
6	Sat	3.6	3.8				0.00	7.45	105	124	13.20	7.34	85	86	14.90	7.31	17	25	11.90	4.6		1.8		0.74	5.5	0.50	
7	Sun	4.7		0.03			0.00	7.49	85	80	11.20	7.28	59	78	12.20	7.16	18	23	10.10	5.2		2.3		0.59	6.1	0.29	
8	Mon	4.0					0.00	7.40	100	93	13.00	7.30	74	78	11.80	7.24	18	24	9.05	4.5		2.1		0.68	5.5	0.39	
9	Tue	4.1		0.02			0.00	7.55	100	104	16.90	7.27	70	76	11.90	7.17	17	23	9.65	4.5		2.3		0.69	5.5	0.35	90
10	Wed	4.4		0.07			0.00	7.45	110	221	11.80	7.32	92	104	15.10	7.26	19	26	11.65	4.6		2.3		0.56	5.5	0.24	
11	Thu	5.5		0.97		6.9	0.00	7.61	135	398	15.00	7.31	97	182	13.40	7.18	17	41	10.20	5.3	80	2.6		0.43	6.7	0.22	
12	Fri	9.9		0.20		22.7	0.00	7.61	33	66	4.07	7.41	37	120	6.04	7.10	15	49	5.22	7.3		3.7	270	0.11	9.9	0.00	
13	Sat	9.9	6.1	0.40		22.9	0.00	7.24	35	68	3.89	7.20	42	102	5.16	7.17	14	30	4.37	7.3		3.7		0.11	9.9	0.01	
14	Sun	6.8		0.02		2.9	0.00	7.41	43	44	5.70	7.30	37	58	5.89	7.17	14	25	4.18	5.3		2.6		0.15	7.1	0.05	
15	Mon	4.2					0.00	7.50	95	65	13.40	7.37	69	70	13.10	7.38	13	29	8.85	4.6		2.1		0.59	5.4	0.30	
16	Tue	4.3					0.00	7.35	78	84	11.20	7.27	61	60	12.90	7.23	13	19	9.00	4.6		2.2		0.59	5.4	0.26	
17	Wed	4.2					0.00	7.37	72	72	12.40	7.26	76	78	18.00	7.17	15	24	11.70	4.6		2.2		0.64	5.4	0.30	
18	Thu	4.3					0.00	7.40	93	80	14.10	7.27	72	70	18.00	7.21	14	22	13.55	4.6		2.2		0.58	5.4	0.27	
19	Fri	4.3					0.00	7.43	73	106	11.50	7.29	65	76	20.70	7.25	12	20	12.50	4.6		1.9		0.53	5.4	0.24	
20	Sat	4.1	4.6				0.00	7.36	88	82	10.40	7.31	65	74	12.70	7.35	14	20	9.60	4.7		1.8		0.60	5.3	0.30	
21	Sun	4.1		0.02			0.00	7.39	90	70	11.80	7.28	70	76	14.50	7.37	14	24	10.10	4.7		1.8		0.59	5.3	0.30	
22	Mon	4.1				0.6	0.00	7.43	97	86	11.20	7.36	85	66	17.10	7.41	17	21	9.98	4.5		2.1		0.60	5.4	0.30	
23	Tue	4.1					0.00	7.39	85	76	14.00	7.31	78	62	18.80	7.18	15	17	13.60	4.6		2.3		0.70	5.3	0.31	
24	Wed	4.1					0.00	7.37	120	82	14.75	7.32	90	74	22.90	7.23	16	22	15.30	4.6		2.3		0.70	5.3	0.30	
25	Thu	5.2		0.15			0.00	7.52	83	116	11.35	7.34	83	84	15.80	7.33	15	33	12.10	4.9		2.8		0.47	5.8	0.11	
26	Fri	3.9					0.00	7.39	50	56	14.40	7.36	36	60	18.60	7.41	15	16	12.70	4.7		2.0		0.68	5.4	0.36	
27	Sat	3.9	4.2				0.00	7.35	95	70	14.05	7.24	77	64	15.70	7.21	16	20	10.80	4.7		1.8		0.65	5.4	0.37	
28	Sun	4.2		0.07			0.00	7.33	80	64	14.20	7.26	66	62	15.25	7.29	13	16	10.50	4.7		1.8		0.56	5.3	0.28	
29	Mon	4.0					0.00	7.43	100	79	15.10	7.33	80	58	21.80	7.31	14	16	15.85	4.6		2.1	180	0.69	5.5	0.38	
30	Tue	3.9					0.00	7.45	95	120	13.40	7.36	84	74	19.90	7.30	14	26	13.00	4.6		2.4		0.77	5.4	0.38	
31	Wed	4.0	4.2				0.00	7.43	91	95	13.50	7.28	77	54	16.50	7.21	12	17	10.00	4.6		2.3		0.74	5.3	0.34	
AVERAGE		4.6		0.06		1.8	0.00	7.43	89	102	12.87	7.31	71	79	15.16	7.27	15	24	10.84	4.8	3	2.3	15	0.60	5.8	0.31	3
MAXIMUM		9.9	6.1	0.97		22.9	0.00	7.61	135	398	25.30	7.42	97	182	22.90	7.41	19	49	15.85	7.3	80	3.7	270	0.89	9.9	0.51	90
MINIMUM		3.6		0.02		0.0	0.00	7.24	33	44	3.89	7.20	36	54	5.16	7.10	12	14	4.18	4.5	80	1.8	180	0.11	5.3	0.00	90
# OF DATA		31		10		31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	1	31	2		31		1
TOTAL		143		1.95		56	0	230	2755	3164	399	227	2201	2444	470	225	471	730	336	150	80	70	450		181		90

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date: Mar-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	Maximum Daily pH	Minimum Daily pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Mon	3.3	7.38	7.09	3		107		5		172		0.43		15		9.7				
2	Tue	2.8	7.39	7.26	3		76		2		61		0.35		11		9.8				
3	Wed	2.8	7.42	7.03	2		64		3		91		0.36		11		10.4				
4	Thu	3.0	7.44	7.19	< 2		32		2		64		0.57		18		10.0				
5	Fri	2.7	7.40	7.30	< 2		30		2		60		0.46		14		10.1				
6	Sat	2.8	7.42	6.85	2	2	61	72	6	4	182	118	0.34	0.42	10	14	10.3				
7	Sun	3.7	7.39	6.90	4		145		9		352		0.44		17		10.1				
8	Mon	3.1	7.41	7.26	2		79		3		99		0.28		9		10.1				
9	Tue	3.2	7.39	7.11	3		99		5		153		0.33		11		10.0				
10	Wed	3.5	7.46	7.24	2		73		5		183		0.42		15		10.0				
11	Thu	4.5	7.41	7.11	5		240		15		691		0.73		34		9.8				
12	Fri	8.5	7.13	6.99	6		526		17		1398		0.40		33		9.6				
13	Sat	8.5	7.19	7.09	6	4	452	231	10	9	823	529	0.27	0.41	22	20	9.7				
14	Sun	5.8	7.17	6.80	4		204		6		311		0.19		11		10.4				
15	Mon	3.3	7.40	7.01	3		94		4		140		0.24		8		10.1				
16	Tue	3.4	7.36	6.80	< 2		36		4		143		0.33		12		9.9				
17	Wed	3.2	7.33	7.01	3		87		5		173		0.35		12		9.6				
18	Thu	3.4	7.26	7.01	3		93		4		126		0.56		20		9.7				
19	Fri	3.4	7.36	7.22	< 2		36		5		179		0.48		17		9.8				
20	Sat	3.2	7.37	7.18	< 2	2	34	83	5	5	170	177	0.37	0.36	13	13	9.6				
21	Sun	3.2	7.36	6.84	< 2		34		7		222		0.24		8		9.7				
22	Mon	3.2	7.33	7.22	2		83		5		173		0.22		8		9.7				
23	Tue	3.1	7.22	7.07	< 2		34		2		51		0.41		14		9.6				
24	Wed	3.1	7.33	6.94	3		102		3		102		0.41		14		9.5				
25	Thu	4.3	7.22	7.03	4		162		7		284		0.55		24		9.5				
26	Fri	3.1	7.29	6.96	3		112		2		66		0.32		11		10.0				
27	Sat	3.1	7.32	6.91	< 2	2	33	80	5	4	164	152	0.30	0.35	10	13	9.8				
28	Sun	3.3	7.34	6.93	< 2		35		2		52		0.19		7		9.5				
29	Mon	3.2	7.28	7.06	< 2		33		1		33		0.31		10		9.7		1.64	1	< 0.01
30	Tue	3.1	7.27	7.09	< 2		33		10		328		0.30		10		9.4		1.71	14	< 0.01
31	Wed	3.2	7.31	7.13	< 2	1	33	39	2		66	147	0.18		6	8	9.2		1.42	7	< 0.01
AVERAGE		3.7			2		105		5		229		0.37		14		9.8		1.59	5	
MAXIMUM		8.5	7.46		6	4	526	231	17	9	1398	529	0.73	0.42	34	20	10.4		1.71	14	
MINIMUM		2.7		6.80	<2		30		1		33		0.18		6		9.2		1.42	1	
# OF DATA		31	31	31	31		31		31		31		31		31		31		3	3	3
TOTAL		114	227	219	74		3260		160		7113		11		434		304.3		4.77	22	

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-10

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection			Primary & Secondary Settling					Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day	Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)	
1	Mon					31	0	282	6	2	83	
2	Tue					34	0	276	6	2	83	
3	Wed					30	0	264	6	2	84	
4	Thu					27	2	286	6	2	82	
5	Fri				34	30	0	286	6	2	83	
6	Sat					30	0	286	6	2	83	
7	Sun					31	0	284	6	2	83	
8	Mon					30	0	277	6	2	83	
9	Tue					30	0	272	6	2	83	
10	Wed			27		22	0	267	6	2	83	
11	Thu			27		36	0	264	6	2	82	
12	Fri			27	41	36	0	266	6	2	83	
13	Sat					30	0	293	6	2	91	
14	Sun					25	0	279	6	5	182	
15	Mon					24	0	290	6	2	97	
16	Tue					23	6	281	6	2	93	
17	Wed					28	0	272	6	2	102	
18	Thu					22	0	264	6	2	103	
19	Fri					29	0	261	6	2	93	
20	Sat					25	0	255	6	2	88	
21	Sun					33	0	254	6	2	85	
22	Mon					33	0	254	6	2	84	
23	Tue					30	3	256	6	2	84	
24	Wed			27	27	26	13	255	6	2	85	
25	Thu					31	0	259	6	2	84	
26	Fri					26	2	253	6	2	86	
27	Sat					24	0	253	6	2	89	
28	Sun					23	0	253	6	2	84	
29	Mon	60	50			22	0	253	6	2	95	
30	Tue	100	70			30	0	254	6	2	108	
31	Wed	120	60			28	0	255	6	2	85	
AVERAGE		9	6	3	3	28	1	268	6	2	91	
MAXIMUM		120	70	27	41	36	13	293	6	5	182	
MINIMUM		60	50	27	27	22	0	253	6	2	82	
# OF DATA		3	3	4	3	31	31	31	31	31	31	
TOTAL		280	180	108	101	877	27	8303	186	73	2815	

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester					Digested Sludge Storage Tank				
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank #1 Volume (gal x 1000)	Storage Tank #2 Volume (gal x 1000)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)
1	Mon		4.27	75.9	6.22	2.73	58.6	6.85	96				50	16	4.16	61.9	6.83	38	0.34		287		
2	Tue								96				50	23				15			309		24
3	Wed								96				50	43				62	1.73		308		
4	Thu								96				50	22				54			308		
5	Fri								96				50	23				54	2.53		307		
6	Sat								96				50	31				50			307		
7	Sun								96				50	29				63			307		
8	Mon		3.79	70.4	6.41	2.82	61.3	6.88	96				50	25	4.05	62.8	6.86	16			330		23
9	Tue								96				50	19				25			331		
10	Wed								96				50	18				35	0.22		331		
11	Thu								96				50	34				56	0.06		333		
12	Fri								96				50	42				77	1.57		335		
13	Sat								96				50	19				51	1.62		337		
14	Sun								96				50	14				39	1.71		337		
15	Mon		4.73	67.9	6.23	3.35	57.6	6.86	96				50	15	4.24	59.4	6.90	42	0.20		320		
16	Tue								96				50	26				24			320		23
17	Wed								96				50	12				19			342		
18	Thu								96				50	14				37			342		
19	Fri								96				50	20				47			342		
20	Sat								96				50	17				45			342		
21	Sun								96				50	23				69	2.16		342		
22	Mon		3.65	72.2	6.32	3.29	57.1	6.85	96				50	32	4.43	60.0	6.92	16			383		42
23	Tue								96				50	12				0			383		
24	Wed								96				50	32				54			382		
25	Thu								96				50	21				57			382		
26	Fri								96				50	19				50			382		
27	Sat								96				50	18				43			381		
28	Sun								96				50	13				37			381		
29	Mon		4.24	71.1	6.37	2.92	59.1	6.89	96				50	30	4.63	60.3	6.88	22			382		52
30	Tue								96				50	26				0			381		38
31	Wed								96				50	12				0			380		
AVERAGE			4.14	71.5	6.31	3.02	58.7	6.87	96				50	23	4.30	60.9	6.88	39	1.21		343		7
MAXIMUM			4.73	75.9	6.41	3.35	61.3	6.89	96				50	43	4.63	62.8	6.92	77	2.53		383		52
MINIMUM			3.65	67.9	6.22	2.73	57.1	6.85	96				50	12	4.05	59.4	6.83	0	0.06		287		0
# OF DATA			5	5	5	5	5	5	31				31	31	5	5	5	31	10	31	31		31
TOTAL			21	358	32	15	294	34	2963				1551	701	22	304	34	1198	12		10634		202

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Mar-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l

INFLUENT								EFFLUENT							
Method: 24 hour composite								Site: Post Disinfection							
Sample Characteristics		Cr	Cu	Pb	Ni	Zn	CN, Free	Cr	Cu	Pb	Ni	Zn	CN, Free		
Sample Number															
Sample Type	Permit Condition	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB		
	Monitored	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB		
Frequency	Permit Condition	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual		
	Monitored	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual		
Parameter Limits	Daily Maximum	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
	Monthly Average	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
1st Date:	March 3, 2010	<0.005	0.057	<0.005	0.007	0.074		<0.005	0.008	<0.005	<0.005	0.016			
2nd Date:	March 17, 2010	<0.005	0.040	<0.005	0.006	0.051	<0.005	<0.005	0.011	<0.005	<0.005	0.016	<0.005		
3rd Date:	March 31, 2010	<0.005	0.038	<0.005	0.005	0.049		<0.005	0.009	<0.005	0.005	0.013			
4th Date:															
5th Date:															
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
Average		<0.003	0.045	<0.003	0.006	0.058	<0.003	<0.003	0.009	<0.003	0.003	0.015	<0.003		
Maximum		<0.005	0.057	<0.005	0.007	0.074	<0.005	<0.005	0.011	<0.005	0.005	0.016	<0.005		

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	6.1	4.6	4	2	231	105	9	5	529	229	0.42	0.37	20	14	9.2	7.46		14	5
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Mar-10
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 6,979

Overall Percent Removal of Volatile Solids 38.0%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 20,045

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 459

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 52

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 759

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 30

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 3

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	20%	23%	-18%
Secondary Treatment :	79%	70%	29%
Adv. Sec. Treatment :	84%	78%	97%
Overall Treatment :	97%	95%	97%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	3.4	1.2	2.7
Secondary Settling Tank	2.5	0.9	2.0
Final Settling Tank	7.8	2.8	6.1
Chlorine Contact Tank	0.54	0.20	0.42
Total Plant Retention Time	13.7	5.0	10.7

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	1233	450	575
Secondary Settling Tank	1628	594	759
Final Settling Tank	830	303	387

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	24	9	11
Secondary Settling Tank	19	7	9
Final Settling Tank	19	7	9

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

March 12, 2010 - Successful test of emergency electrical power system

March 12, 2010 - Re-started north 1/2 of the Fixed-bed Trickling Filter. Each winter 1/2 of the Fixed-bed Trickling Filter is shut down to minimize temperature loss and improve nitrification.

March 29, 2010 - Disinfection system started

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
CSO DISCHARGE MONITORING REPORT (CSO DMR)

STATE FORM 50546 (9-01)

City: La Porte	Page:	1 of 1
Facility: La Porte Wastewater Treatment Facility	Permit Number:	IN0025577
Monitoring Period: (MM/DD/YY to MM/DD/YY)	03/01/2010 03/31/2010	Check box if no CSO discharge occurred for the month: X

Design Peak Inf. Flow(MGD)	9.7	Measured/Metered (M) or Estimated (E) must be specified.(Please attach methods used.)
----------------------------	------------	---

					CSO Outfall No. 002						CSO Outfall No.						CSO Outfall No.						
Day of Month	Day of Week	Precip. in Inches	Avg Infl. Flow Rate (MGD)	Peak Infl. Flow Rate (MGD)	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	
1	Mon		4.14	6.53																			
2	Tue		3.64	4.58																			
3	Wed		3.64	4.67																			
4	Thu		3.85	4.98																			
5	Fri		3.60	4.49																			
6	Sat		3.64	4.69																			
7	Sun	0.03	4.69	8.13																			
8	Mon		3.97	6.30																			
9	Tue	0.02	4.07	6.40																			
10	Wed	0.07	4.40	6.86																			
11	Thu	0.97	5.52	10.01																			
12	Fri	0.20	9.86	10.16																			
13	Sat	0.40	9.86	10.21																			
14	Sun	0.02	6.79	10.12																			
15	Mon		4.19	4.78																			
16	Tue		4.28	5.08																			
17	Wed		4.15	4.69																			
18	Thu		4.30	4.99																			
19	Fri		4.30	5.12																			
20	Sat		4.07	4.89																			
21	Sun	0.02	4.09	4.94																			
22	Mon		4.15	5.27																			
23	Tue		4.06	4.61																			
24	Wed		4.06	4.73																			
25	Thu	0.15	5.25	9.78																			
26	Fri		3.94	4.49																			
27	Sat		3.93	4.70																			
28	Sun	0.07	4.17	4.92																			
29	Mon		3.99	4.81																			
30	Tue		3.93	4.44																			
31	Wed		3.98	4.69																			
Totals:		1.95	n/a	n/a	n/a		0.0		0.00														

Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent	Telephone
Jerry P Jackson, Superintendent	219-362-2354

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

Signature of Principal Executive Officer or Authorized Agent	Date
	11/03/2010