

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Nov-06
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters		Biotowers				
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Wed	2.4					0.00	7.63	180	119	46.01	7.58	98	54	31.30	7.63	15	16	17.37	4.7		2.3		1.96	5.0	1.11	
2	Thu	2.0					0.00	7.82	155	216	33.62	7.64	125	74	38.94	7.77	12	21	26.01	4.7		2.3		2.60	5.3	1.69	
3	Fri	2.6					0.00	7.86	390	126	41.09	7.70	75	51	31.95	7.71	12	19	26.18	4.8		1.9		1.57	5.1	0.95	
4	Sat	3.1	2.4				0.00	7.78	102	100	22.60	7.55	69	52	25.02	7.63	15	18	17.17	4.8		1.7		1.08	5.0	0.58	
5	Sun	1.9					0.00	7.69	115	76	29.71	7.56	120	96	33.47	7.44	11	18	16.93	4.8		1.8		2.37	5.2	1.72	
6	Mon	1.9					0.00	7.78	145	180	45.17	7.56	120	78	46.75	7.52	14	19	31.70	4.7		2.1	240	2.54	5.3	1.76	
7	Tue	2.9		0.01			0.00	7.65	130	114	46.31	7.49	74	64	31.26	7.52	16	28	26.22	4.7		2.3		1.39	5.0	0.70	
8	Wed	1.8					0.00	7.70	295	165	42.19	7.60	165	80	38.97	7.55	22	23	24.54	4.7		2.2		2.76	5.2	1.85	
9	Thu	2.0					0.00	7.76	230	232	42.05	7.59	163	54	42.19	7.52	18	19	28.57	4.7		2.3		2.42	5.4	1.62	
10	Fri	3.1		0.56		4.0	0.00	7.79	350	748	40.01	7.54	141	97	42.19	7.58	18	22	35.89	5.0	60	2.3		1.38	6.0	0.95	
11	Sat	5.0	2.7	0.05			0.00	7.61	91	48	11.21	7.56	76	50	12.57	7.56	29	33	9.50	5.0		1.9		0.36	6.0	0.19	
12	Sun	1.8					0.00	7.81	81	76	29.30	7.51	98	48	26.20	7.50	14	16	15.93	4.8		1.7		2.69	5.3	1.99	
13	Mon	1.9		0.05			0.00	7.85	195	140	34.78	7.62	107	54	37.36	7.69	14	18	23.65	4.4		2.1		2.50	5.3	1.83	60
14	Tue	2.8		0.05			0.00	7.72	140	104	25.82	7.57	108	46	32.31	7.58	33	18	24.99	4.7		2.3		1.51	5.1	0.81	
15	Wed	3.1		0.25		1.2	0.00	7.82	145	177	29.90	7.61	93	46	34.06	7.60	12	15	20.64	4.9		2.4		1.40	5.5	0.78	
16	Thu	5.6		0.31		4.1	0.00	7.63	78	134	16.42	7.61	73	78	18.10	7.65	23	31	14.32	5.6		2.9		0.50	6.9	0.23	
17	Fri	2.5					0.00	7.76	94	139	28.73	7.54	97	38	27.20	7.50	13	11	13.05	4.8		1.9		1.68	5.2	1.08	
18	Sat	1.8	2.8	0.03			0.00	7.74	145	130	33.64	7.51	120	62	31.92	7.43	14	17	20.73	4.8		1.8		2.64	5.3	1.92	
19	Sun	4.7		0.46		2.7	0.00	7.67	72	84	12.94	7.51	62	56	17.48	7.50	21	25	15.40	5.4		2.4		0.67	6.6	0.42	
20	Mon	2.3					0.00	7.81	117	71	26.31	7.54	62	36	21.54	7.44	10	11	11.65	4.7		2.1		1.98	5.4	1.32	
21	Tue	1.9					0.00	7.74	155	98	32.66	7.61	101	56	37.43	7.60	13	11	24.55	4.7		2.3		2.68	5.2	1.73	
22	Wed	2.9					0.00	7.58	150	276	36.49	7.51	86	50	29.79	7.52	15	17	17.46	4.7		2.3		1.44	5.0	0.75	
23	Thu	2.0					0.00	7.67	170	110	29.79	7.45	100	52	30.74	7.48	11	12	18.17	4.7		2.3		2.44	5.4	1.64	
24	Fri	2.3					0.00	7.62	120	126	31.57	7.48	86	79	35.20	7.45	11	14	19.75	4.8		1.9		1.87	5.1	1.20	
25	Sat	1.8	2.6				0.00	7.76	122	132	35.64	7.53	85	66	43.23	7.52	11	17	31.31	4.8		1.8		2.62	5.3	1.93	
26	Sun	2.5					0.00	7.57	135	86	26.67	7.50	89	56	28.71	7.45	12	16	21.96	4.8		1.7		1.63	5.1	1.07	
27	Mon	1.9					0.00	7.63	200	132	40.23	7.50	133	54	42.09	7.45	13	10	26.63	4.7		2.1		2.65	5.3	1.87	
28	Tue	2.8					0.00	7.61	120	120	33.77	7.47	103	66	36.74	7.42	15	22	27.13	4.7		2.3		1.51	5.1	0.84	
29	Wed	4.6		0.96		4.7	0.00	7.58	111	124	34.20	7.46	93	104	21.60	7.52	21	28	19.30	5.4		2.7		0.78	6.4	0.41	
30	Thu	8.5	4.8	1.27		12.9	0.00	7.76	63	92	8.15	7.35	53	56	10.50	7.15	20	27	7.24	6.7		3.5		0.20	9.3	0.09	
AVERAGE		2.9		0.13		1.0	0.00	7.71	153	149	31.57	7.54	99	62	31.23	7.53	16	19	21.13	4.9	2	2.2	8	1.79	5.5	1.17	2
MAXIMUM		8.5	4.8	1.27		12.9	0.00	7.86	390	748	46.31	7.70	165	104	46.75	7.77	33	33	35.89	6.7	60	3.5	240	2.76	9.3	1.99	60
MINIMUM		1.8		0.01		0.0	0.00	7.57	63	48	8.15	7.35	53	36	10.50	7.15	10	10	7.24	4.4	60	1.7	240	0.36	5.0	0.19	60
# OF DATA		30		11		30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	1	30	1		30		1
TOTAL		86		4.00		30	0	231	4597	4475	947	226	2974	1853	937	226	474	572	634	147	60	66	240		166		60

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date: Nov-06 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies) /100mL	Effluent Chlorine Residual in mg/L
1	Wed	2.4	7.80	3		68		3		60		0.93		19		9.6		2.61		< 0.01
2	Thu	2.0	7.85	2		33		5		78		0.83		14		9.5				
3	Fri	2.6	7.92	4		76		4		87		1.55		34		9.0				
4	Sat	3.2	7.81	4	3	102	63	7	5	170	93	0.96	0.92	25	19	9.6				
5	Sun	2.1	7.83	7		108		11		181		3.24		52		9.8				
6	Mon	2.0	7.95	4		56		6		97		1.14		18		9.2				
7	Tue	3.0	7.73	4		108		9		209		1.06		26		9.1				
8	Wed	2.0	7.79	4		60		5		76		0.66		10		8.9				
9	Thu	2.2	7.79	3		56		6		102		1.02		17		8.8				
10	Fri	3.0	7.83	6		155		15		369		0.95		24		8.8				
11	Sat	5.1	7.56	13	6	533	154	14	9	567	229	2.89	1.57	121	39	9.4				
12	Sun	1.9	7.69	5		72		7		100		0.82		12		10.0				
13	Mon	2.0	7.71	4		60		5		78		0.86		13		9.9				
14	Tue	2.9	7.68	14		322		4		99		0.98		23		9.0				
15	Wed	3.0	7.63	3		82		6		141		0.93		24		9.4				
16	Thu	5.6	7.51	9		433		13		612		3.81		179		9.3				
17	Fri	2.6	7.71	5		109		5		104		1.11		23		10.0				
18	Sat	1.9	7.71	3	6	44	160	7	7	98	176	0.66	1.31	10	41	9.7				
19	Sun	4.6	7.71	7		268		10		378		2.66		103		9.2				
20	Mon	2.4	7.62	5		87		5		87		0.49		9		9.9				
21	Tue	2.0	7.68	4		58		3		52		0.69		11		9.6				
22	Wed	2.9	7.71	4		91		5		108		0.73		18		9.7				
23	Thu	2.1	7.59	3		43		5		85		1.10		19		9.4				
24	Fri	2.4	7.57	4		72		4		78		0.52		10		9.4				
25	Sat	1.9	7.65	4	4	57	96	8	6	113	129	0.58	0.97	9	26	9.5				
26	Sun	2.6	7.60	4		74		8		165		0.61		13		9.4				
27	Mon	2.0	7.70	4		56		5		78		0.52		8		9.2				
28	Tue	2.9	7.43	20		456		10		220		0.77		18		8.8				
29	Wed	4.5	7.66	7		263		13		476		0.87		33		8.8				
30	Thu	8.2	7.13	9	8	654	311	11	8	799	352	0.66	0.60	47	23	9.5				
AVERAGE		2.9	7.69	6		155		7		196		1.15		31		9.4		2.61		< 0.01
MAXIMUM		8.2	7.95	20	8	654	311	15	9	799	352	3.81	1.57	179	41	10.0		2.61		
MINIMUM		1.9	7.13	2		33		3		52		0.49		8		8.8		2.61		0.00
# OF DATA		30	30	30		30		30		30		30		30		30		1		1
TOTAL		88	231	168		4653		214		5866		35		943		281.4		2.61		< 0.01

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Nov-06

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection						Primary & Secondary Settling			Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day		Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)	
1	Wed						20	11	301	6	2	118	
2	Thu						20	0	300	6	2	116	
3	Fri				27	27	20	0	303	6	2	118	
4	Sat						20	6	305	6	2	118	
5	Sun						20	0	301	6	2	116	
6	Mon						18	8	301	6	2	122	
7	Tue						20	0	301	6	2	125	
8	Wed						20	0	301	6	2	116	
9	Thu						20	0	304	6	2	116	
10	Fri				20	34	22	0	311	6	2	108	
11	Sat						23	0	320	6	2	107	
12	Sun						20	0	320	6	2	118	
13	Mon						20	0	322	6	2	116	
14	Tue						20	0	319	6	2	118	
15	Wed						21	5	312	6	2	107	
16	Thu						27	0	317	6	1	77	
17	Fri				27		20	0	320	6	2	116	
18	Sat						20	0	313	6	2	115	
19	Sun						23	0	312	6	2	115	
20	Mon						20	0	314	6	2	114	
21	Tue				14	34	20	0	308	6	2	116	
22	Wed						20	0	302	6	2	114	
23	Thu						20	0	299	6	2	114	
24	Fri						20	0	300	6	2	113	
25	Sat						20	0	298	6	2	113	
26	Sun						20	0	299	6	2	113	
27	Mon						20	0	298	6	2	110	
28	Tue						20	0	300	6	2	113	
29	Wed						20	0	304	6	2	94	
30	Thu				20	41	20	11	308	6	1	35	
AVERAGE					4	5	20	1	307	6	2	110	
MAXIMUM					27	41	27	11	322	6	2	125	
MINIMUM					14	27	18	0	298	6	1	35	
# OF DATA					5	4	30	30	30	30	30	30	
TOTAL					108	135	615	41	9214	180	64	3309	

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Nov-06
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester				Digested Sludge Storage Tank			
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)
1	Wed								96				96	19				2		9.4	17
2	Thu								96				96	15				4		7.8	10
3	Fri								96				96	8				11		75.4	
4	Sat								96				96	15				41		66.5	
5	Sun								96				96	13				34		29.7	
6	Mon		2.65	67.3	6.68	1.55	61.5	6.82	96	3.42	59.9	6.93	96	38	3.69	55.8	7.04	12		10.1	43
7	Tue								96				96	2				0		0.1	
8	Wed								96				96	6				1		0.0	
9	Thu								96				96	14				33		0.0	
10	Fri								96				96	11				33		0.0	3
11	Sat								96				96	9				22		0.0	
12	Sun								96				96	14				43	0.06	0.0	
13	Mon		0.79	69.6	6.34	2.09	62.2	6.93	96	1.99	56.8	7.24	96	23	3.73	58.1	6.98	6		0.0	25
14	Tue								96				96	10				0		0.0	10
15	Wed								96				96	13				27		0.0	
16	Thu								96				96	21				53		0.0	
17	Fri								96				96	16				39		0.0	
18	Sat								96				96	13				36		0.0	
19	Sun								96				96	19				52		0.0	
20	Mon		2.63	76.1	6.43	1.75	56.5	6.86	96	1.89	51.6	7.08	96	31	3.34	55.2	7.07	9		0.1	40
21	Tue								96				96	8				0		0.1	
22	Wed								96				96	13				20		0.1	
23	Thu								96				96	13				36		0.1	
24	Fri								96				96	16				43		0.1	
25	Sat								96				96	15				42	0.17	0.1	
26	Sun								96				96	12				36	0.15	0.1	
27	Mon		2.59	83.5	6.32	1.45	63.9	6.95	96	1.79	64.9	6.98	96	13	4.08	61.6	7.02	37		0.1	
28	Tue								96				96	13				38		0.1	
29	Wed								96				96	12				39		0.1	
30	Thu								96				95	27				73		0.1	
AVERAGE			2.17	74.1	6.44	1.71	61.0	6.89	96	2.27	58.3	7.06	96	15	3.71	57.7	7.03	27	0.13	6.7	5
MAXIMUM			2.65	83.5	6.68	2.09	63.9	6.95	96	3.42	64.9	7.24	96	38	4.08	61.6	7.07	73	0.17	75.4	43
MINIMUM			0.79	67.3	6.32	1.45	56.5	6.82	96	1.79	51.6	6.93	95	2	3.34	55.2	6.98	0	0.06	0.0	
# OF DATA			4	4	4	4	4	4	30	4	4	4	30	30	4	4	4	30	3	30	30
TOTAL			9	297	26	7	244	28	2873	9	233	28	2874	454	15	231	28	824	0	200	148

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Nov-06
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l except mercury (Hg) which is given in ng/l.

INFLUENT									EFFLUENT						
Method: 24 hour composite (except for Hg, which is grab)									Site: Post Rake Room						
Site: Post Cl2 Tank															
Sample Characteristics		Hg	Cr	Cu	Pb	Ni	Zn	CN-	Hg	Cr	Cu	Pb	Ni	Zn	CN-
Sample Number		CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720	CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720
Sample Type	Permit Condition	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
	Monitored	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
Frequency	Permit Condition	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
	Monitored	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
Parameter Limits	Daily Maximum										0.055				0.016
	Monthly Average										0.024				0.016
1st Date :	November 1st		<0.005	0.097	<0.005	0.026	0.097	<0.005			0.027				<0.005
2nd Date :	November 8th			0.098							0.020				
3rd Date :	November 15th		<0.005	0.086	<0.005	0.010	0.094	<0.005			0.019				<0.005
4th Date :	November 22nd			0.110							0.015				
5th Date :	November 29th			0.083							0.020				
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	*See Note	0	NA	NA	0
Average			<0.003	0.095	<0.003	0.018	0.096	<0.003			0.020				<0.003
Maximum			<0.005	0.110	<0.005	0.026	0.097	<0.005			0.027				<0.005

* We are currently under Agreed Order 2000-9996-W with IDEM to resolve effluent copper concerns.

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	30	20	2504	1669	36	24	3004	2003	2.40	1.60	200	134	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	4.8	2.9	8	6	311	155	9	7	352	196	1.57	1.15	41	31	8.8	7.95			
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Nov-06
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 2,742

Overall Percent Removal of Volatile Solids 52.4%

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	35%	59%	1%
Secondary Treatment :	84%	69%	32%
Adv. Sec. Treatment :	65%	63%	95%
Overall Treatment :	96%	95%	96%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 21,662

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 462

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	6.9	1.4	4.2
Secondary Settling Tank	5.1	1.1	3.1
Final Settling Tank	15.8	3.3	9.8
Chlorine Contact Tank	1.09	0.23	0.67
Total Plant Retention Time	27.8	5.8	17.1

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 50

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 721

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 27

Surface Flow Rate	Maximum	Minimum	Average
Gallons per sq ft per Day			
Primary Settling Tank	1065	222	360
Secondary Settling Tank	1406	293	476
Final Settling Tank	717	149	242

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 3

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 2

Weir OverFlow Rate	Maximum	Minimum	Average
1000 Gal per ft per Day			
Primary Settling Tank	21	4	7
Secondary Settling Tank	17	4	6
Final Settling Tank	16	3	6

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

November 8, 21, 28 - Successful test of WWTP emergency power system

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 CSO DISCHARGE MONITORING REPORT (CSO DMR)

STATE FORM 50546 (9-01)

City: La Porte	Page: 1 of 1
Facility: La Porte Wastewater Treatment Facility	Permit Number: IN0025577
Monitoring Period: (MM/DD/YY to MM/DD/YY) 11/01/2006 to 11/30/2006	Check box if no CSO discharge occurred for the month: <input checked="checked" type="checkbox"/>

Design Peak Inf. Flow(MGD) 9.7	Measured/Metered (M) or Estimated (E) must be specified.(Please attach methods used.)
---------------------------------------	---

Day of Month	Day of Week	Precip. in Inches	Avg Infl. Flow Rate (MGD)	Peak Infl. Flow Rate (MGD)	CSO Outfall No. 002						CSO Outfall No.						CSO Outfall No.						
					Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	
1	Wed		2.40	3.45																			
2	Thu		1.97	3.08																			
3	Fri		2.60	4.09																			
4	Sat		3.13	4.19																			
5	Sun		1.93	3.01																			
6	Mon		1.93	2.86																			
7	Tue	0.01	2.94	3.87																			
8	Wed		1.83	2.48																			
9	Thu		2.04	3.25																			
10	Fri	0.56	3.06	10.05																			
11	Sat	0.05	5.03	9.95																			
12	Sun		1.77	2.71																			
13	Mon	0.05	1.88	2.66																			
14	Tue	0.05	2.80	3.79																			
15	Wed	0.25	3.07	10.05																			
16	Thu	0.31	5.65	10.08																			
17	Fri		2.50	5.09																			
18	Sat	0.03	1.81	2.72																			
19	Sun	0.46	4.65	10.14																			
20	Mon		2.31	5.57																			
21	Tue		1.92	2.50																			
22	Wed		2.88	3.95																			
23	Thu		2.04	3.30																			
24	Fri		2.33	3.62																			
25	Sat		1.81	3.08																			
26	Sun		2.47	3.81																			
27	Mon		1.86	2.63																			
28	Tue		2.77	3.90																			
29	Wed	0.96	4.56	10.08																			
30	Thu	1.27	8.52	10.16																			
31																							
Totals:		4	n/a	n/a	n/a		0.0	0.00															

Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent
Jerry P Jackson, Superintendent

Telephone
219-362-2354

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

Signature of Principal Executive Officer or Authorized Agent
Jerry P Jackson

Date
04/23/2007