

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Sep-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters		Biotowers				
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow in MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Thu	2.1					0.00	7.77	150	172	27.77	7.61	85	86	25.87	7.24	10	13	8.92	4.9		3.4		3.00	8.2	2.96	
2	Fri	3.0					0.00	7.56	97	108	21.06	7.46	73	60	21.30	7.23	12	17	8.24	5.0		4.1		2.01	7.7	1.56	
3	Sat	3.1					0.00	7.55	107	78	21.01	7.42	73	48	19.05	7.21	11	10	6.95	5.1		4.1		1.98	7.7	1.53	
4	Sun	2.0					0.00	7.74	190	98	30.24	7.46	112	58	27.47	7.28	12	18	8.51	5.0		2.8		2.97	7.8	2.95	
5	Mon	1.8					0.00	7.67	200	121	30.83	7.43	117	46	29.05	7.16	12	10	11.10	5.0		2.9		3.29	7.8	3.29	
6	Tue	1.8					0.00	7.60	210	132	31.67	7.42	115	52	25.51	7.18	12	13	8.37	4.9		4.1		3.98	8.3	3.58	
7	Wed	1.9					0.00	7.52	205	164	31.58	7.37	148	53	28.21	7.17	12	14	9.67	4.9		3.1		3.25	8.2	3.41	60
8	Thu	3.7		0.16		1.2	0.00	7.45	205	256	18.39	7.26	99	82	22.24	7.11	15	28	9.12	5.1	40	3.7		1.39	8.6	1.34	
9	Fri	2.2					0.00	7.62	165	120	28.30	7.37	65	38	25.51	7.18	13	12	9.43	4.9		3.4		2.69	7.8	2.45	
10	Sat	1.7	2.2				0.00	7.65	160	108	30.17	7.41	109	60	27.73	7.18	12	17	10.38	5.0		2.3		3.22	7.8	3.51	
11	Sun	1.7					0.00	7.70	180	86	31.58	7.44	37	50	30.07	7.20	12	15	12.26	5.0		2.5		3.31	7.8	3.48	
12	Mon	1.9					0.00	7.63	205	171	31.63	7.52	119	70	27.50	7.23	13	22	10.42	4.9		2.9		3.10	7.8	3.10	
13	Tue	2.7					0.00	7.63	145	114	22.64	7.42	99	54	19.92	7.18	13	18	7.88	4.9		3.5		2.09	8.2	2.02	
14	Wed	3.8		0.37		1.0	0.00	7.50	111	152	17.10	7.30	82	48	16.04	7.08	13	17	5.28	5.1		3.9		1.35	8.7	1.29	
15	Thu	2.9		0.30		2.0	0.00	7.89	190	144	26.31	7.45	105	52	25.93	7.21	13	23	9.98	5.1		3.3		1.89	8.5	1.95	
16	Fri	5.3		0.05		2.3	0.00	7.28	83	130	10.10	7.26	48	71	9.39	6.97	14	24	4.72	5.3		4.0		0.75	8.3	0.56	
17	Sat	3.0	3.1				0.00	7.41	97	68	19.49	7.25	70	56	21.80	7.00	11	18	8.71	5.0		4.0		1.95	8.3	1.72	
18	Sun	3.1					0.00	7.50	145	120	18.40	7.28	75	36	18.62	6.98	12	16	6.89	5.0		3.9		1.85	7.8	1.50	
19	Mon	4.8		0.34		2.1	0.00	7.52	104	131	12.63	7.29	65	72	11.86	7.10	17	37	5.09	5.2		3.8		0.89	8.3	0.74	
20	Tue	2.3					0.00	7.43	115	120	24.96	7.34	62	50	18.14	6.98	13	18	6.04	4.9		3.4		2.58	8.2	2.55	
21	Wed	2.0					0.00	7.65	175	132	30.97	7.47	60	60	25.06	7.08	11	24	7.68	4.9		3.4		3.19	8.3	3.21	
22	Thu	3.2		0.34		1.2	0.00	7.67	104	126	25.54	7.54	93	60	22.90	7.25	15	18	7.88	5.0		3.5		1.70	8.5	1.71	
23	Fri	2.9		0.01			0.00	7.64	86	124	20.20	7.41	85	59	21.20	7.16	14	19	7.93	4.9		3.7		2.02	7.8	1.72	
24	Sat	2.4	2.9				0.00	7.59	83	88	22.77	7.45	76	78	22.77	7.21	13	25	7.75	5.0		3.4		2.48	7.8	2.24	
25	Sun	2.9		0.29			0.00	7.71	178	162	21.62	7.45	100	70	24.06	7.18	26	32	13.52	5.2		3.0		1.78	8.2	1.80	
26	Mon	2.7		0.06		1.5	0.00	7.58	102	94	21.83	7.39	91	44	20.66	7.26	13	14	7.93	4.9		3.4	420	2.07	7.8	1.89	
27	Tue	2.8					0.00	7.57	113	86	20.16	7.42	66	64	17.49	7.21	13	30	5.07	4.8	45	3.8		2.09	8.3	1.96	
28	Wed	3.7		0.94		5.4	0.00	7.72	90	169	17.45	7.55	78	70	16.82	7.29	17	31	10.11	5.5		3.4		1.42	8.5	1.29	
29	Thu	6.1				3.1	0.00	7.66	13	66	8.55	7.47	43	36	8.97	7.28	14	22	5.41	5.3		4.0		0.53	8.9	0.46	
30	Fri	4.9	3.8				0.00	7.60	65	80	11.66	7.43	61	69	15.31	7.29	15	32	7.96	4.9		4.0		0.84	7.8	0.60	
AVERAGE		2.9		0.10		0.7	0.00	7.60	136	124	22.89	7.41	84	58	21.55	7.17	13	20	8.31	5.0	3	3.5	14	2.19	8.1	2.08	2
MAXIMUM		6.1	3.8	0.94		5.4	0.00	7.89	210	256	31.67	7.61	148	86	30.07	7.29	26	37	13.52	5.5	45	4.1	420	3.98	8.9	3.58	60
MINIMUM		1.7		0.01		0.0	0.00	7.28	13	66	8.55	7.25	37	36	8.97	6.97	10	10	4.72	4.8	40	2.3	420	0.75	7.7	0.56	60
# OF DATA		30		10		30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	2	30	1		30		1
TOTAL		88		2.86		20	0	228	4072	3720	687	222	2512	1752	646	215	404	607	249	150	85	105	420		244		60

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date: Sep-05 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Thu	2.2	7.72	3		45		3		48		0.23		4		7.9		3.23	32	< 0.01
2	Fri	3.0	7.69	4		93		10		252		0.29		7		7.9		3.43	58	< 0.01
3	Sat	3.1	7.40	2		51		3		77		<0.20		3		8.0		3.41	17	< 0.01
4	Sun	2.0	7.58	3		49		7		107		0.34		6		7.9		3.30	7	< 0.01
5	Mon	1.9	7.40	4		56		4		53		0.32		5		7.9		4.24	3	< 0.01
6	Tue	1.8	7.60	4		63		5		68		<0.20		2		7.8		2.50	18	< 0.01
7	Wed	1.9	7.52	2		31		2		31		0.26		4		7.7		3.80	15	< 0.01
8	Thu	3.7	7.41	5		160		11		347		0.55		17		7.7		3.12	5	< 0.01
9	Fri	2.4	7.46	3		54		1		19		0.28		5		7.6		3.01	9	< 0.01
10	Sat	1.9	7.48	3	3	43	65	6	5	86	101	0.44	0.33	6	6	7.5		2.64	12	< 0.01
11	Sun	1.8	7.47	7		101		5		72		0.26		4		7.8		1.93	13	< 0.01
12	Mon	2.0	7.38	3		46		8		119		0.24		4		7.5		2.85	21	< 0.01
13	Tue	2.8	7.38	4		79		7		148		0.67		15		7.7		3.34	73	< 0.01
14	Wed	3.8	7.34	6		175		11		335		0.36		11		7.7		2.67	20	< 0.01
15	Thu	2.9	7.42	4		101		16		391		<0.20		2		7.9		2.87	83	< 0.01
16	Fri	5.3	7.24	6		273		12		506		1.83		81		8.5		2.82	7	< 0.01
17	Sat	3.0	7.25	3	5	76	122	7	9	177	250	0.71	0.59	18	19	8.3		3.02	44	< 0.01
18	Sun	3.1	7.19	5		117		6		162		<0.20		3		8.2		3.12	48	< 0.01
19	Mon	4.7	7.26	6		235		16		617		0.74		29		8.3		3.49	148	< 0.01
20	Tue	2.4	7.03	5		99		9		165		<0.20		2		7.8		1.00	79	< 0.01
21	Wed	2.1	7.65	3		54		10		164		0.30		5		7.7		2.17	51	< 0.01
22	Thu	3.1	7.54	5		126		8		211		0.29		8		7.7		3.55	22	< 0.01
23	Fri	2.9	7.58	4		83		7		155		0.31		7		7.9		1.00	9	< 0.01
24	Sat	2.6	7.39	4	4	76	113	14	10	271	249	0.21	0.29	4	8	8.1		3.18	32	< 0.01
25	Sun	3.0	7.36	9		210		17		409		3.49		85		8.0		1.92	15	< 0.01
26	Mon	2.8	7.58	4		83		4		90		1.29		29		7.8		2.37	8	< 0.01
27	Tue	2.8	7.39	5		121		9		204		0.33		8		8.2		2.42	65	< 0.01
28	Wed	3.6	7.46	7		219		11		324		4.86		150		8.2		2.39	37	< 0.01
29	Thu	6.0	7.62	6		310		11		572		4.20		214		8.6		3.08	1	< 0.01
30	Fri	4.9	7.28	6	6	260	194	17	12	691	385	1.70	2.53	69	86	8.8		2.95	86	< 0.01
AVERAGE		3.0	7.43	4		116		8		229		0.83		27		8.0		2.83	21	< 0.01
MAXIMUM		6.0	7.72	9	6	310	194	17	12	691	385	4.86	2.53	214	86	8.8		4.24	148	< 0.01
MINIMUM		1.8	7.03	2		31		1		19		<0.20		2		7.5		1.00	1	< 0.01
# OF DATA		30	30	30		30		30		30		30		30		30		30	30	30
TOTAL		90	223	133		3493		251		6867		25		805		238.6		84.82	1038	< 0.01

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Sep-05

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used						Primary & Secondary Settling			Final Settling		
		for disinfection											
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day	Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)		
1	Thu	180	60			26	0	301	6	4	195		
2	Fri	200	120			26	11	308	6	4	196		
3	Sat	240	100			26	0	305	6	4	193		
4	Sun	120	60			26	0	303	6	4	195		
5	Mon	140	60			26	0	302	6	4	197		
6	Tue	120	60			26	0	299	6	4	191		
7	Wed	140	60			26	0	310	6	4	196		
8	Thu	170	120		14	29	0	304	6	4	200		
9	Fri	100	70			26	0	303	6	4	203		
10	Sat	80	60			26	0	302	6	4	197		
11	Sun	170	80			26	0	300	6	4	196		
12	Mon	130	170	27	20	26	0	300	6	4	198		
13	Tue	180	80			26	0	300	6	4	197		
14	Wed	260	120			29	5	300	6	4	177		
15	Thu	190	100	7		27	0	301	6	4	192		
16	Fri	240	80			28	0	307	6	3	154		
17	Sat	160	200			26	16	308	6	3	193		
18	Sun	190	70			26	0	305	6	4	193		
19	Mon	260	130			29	0	304	6	4	192		
20	Tue	120	80	20	27	26	0	303	6	4	190		
21	Wed	120	80			26	0	301	6	4	191		
22	Thu	300	110			27	0	300	6	4	190		
23	Fri	100	60			28	0	302	6	4	189		
24	Sat	180	90			26	0	301	6	4	189		
25	Sun	120	100			29	0	300	6	3	142		
26	Mon	140	80	20	27	26	0	302	6	4	190		
27	Tue	160	80			26	0	301	6	4	189		
28	Wed	200	100			29	0	301	6	4	182		
29	Thu	300	160			30	0	309	6	3	138		
30	Fri	200	170			26	0	312	6	4	189		
AVERAGE		174	97	2	3	27	1	303	6	4	188		
MAXIMUM		300	200	27	27	30	16	312	6	4	203		
MINIMUM		80	60	7	14	26	0	299	6	3	138		
# OF DATA		30	30	4	4	30	30	30	30	30	30		
TOTAL		5210	2910	74	88	807	32	9094	180	128	5636		

Secondary Digester		Date:
Sample Taken by Grab Method		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Sep-05

LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 4 of 6

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

		Raw Sludge				Primary Digester #1				Primary Digester #2				Secondary Digester				Digested Sludge Storage Tank				
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)	
1	Thu								96				96	16				43			1.2	
2	Fri								96				96	32				75			1.2	
3	Sat								96				96	18				45			1.2	
4	Sun								96				96	19				48			1.2	
5	Mon		1.14	69.9	6.54	1.61	53.3	6.74	96	1.49	56.3	7.03	96	38	4.33	53.8	6.99	25	0.13		1.2	39
6	Tue								96				96	4				25				
7	Wed								96				97	17				39			1.2	
8	Thu								96				97	16				49			22.1	
9	Fri								96				97	22				54			8.7	
10	Sat								96				97	19				43			2.8	
11	Sun								96				97	18				45			1.3	
12	Mon		0.96	69.5	6.45	3.57	57.5	6.88	96	1.98	60.9	6.90	96	32	4.29	54.1	7.01	11			13.4	38
13	Tue								96				96	7				4			12.5	
14	Wed								96				96	21				47			7.9	
15	Thu								96				96	20				52			1.7	
16	Fri								96				96	19				47			2.5	
17	Sat								96				96	37				79			1.6	
18	Sun								96				96	24				49			1.1	
19	Mon		0.48	59.6	6.71	1.71	57.0	6.93	96	1.92	57.1	7.17	96	34	4.87	55.9	7.05	11			1.2	38
20	Tue								96				96	7				3			1.3	
21	Wed								96				96	15				37			1.3	
22	Thu								96				96	14				39			1.3	
23	Fri								96				96	21				53			24.9	
24	Sat								96				96	20				51			28.1	
25	Sun								96				96	21				56			29.2	
26	Mon		0.41	62.8	6.21	1.62	63.3	6.38	96	3.65	60.3	6.82	96	33	4.45	56.2	6.99	20			4.1	36
27	Tue								96				96	9				4			0.4	
28	Wed								96				96	19				42			2.0	
29	Thu								96				96	18				47			2.8	
30	Fri								96				96	23				57			23.1	
AVERAGE			0.75	65.5	6.48	2.13	57.8	6.73	96	2.26	58.7	6.98	96	20	4.49	55.0	7.01	40	0.13		6.8	5
MAXIMUM			1.14	69.9	6.71	3.57	63.3	6.93	96	3.65	60.9	7.17	97	38	4.87	56.2	7.05	79	0.13		29.2	39
MINIMUM			0.41	59.6	6.21	1.61	53.3	6.38	96	1.49	56.3	6.82	96	4	4.29	53.8	6.99	3	0.13			
# OF DATA			4	4	4	4	4	4	30	4	4	4	30	30	4	4	4	30	1		30	30
TOTAL			3	262	26	9	231	27	2876	9	235	28	2882	613	18	220	28	1203	0		203	151

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 5 of 6

Date: Sep-05

LaPorte Wastewater Treatment Plant
2101 Boyd Boulevard
LaPorte IN, 46350
Phone # (219)362-2354

Permit # IN0025577

Expires 10-31-2009

Certified Operator : Jerry P Jackson

Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l except mercury (Hg) which is given in ng/l.

INFLUENT									EFFLUENT						
Method: 24 hour composite (except for Hg, which is grab)									Site: Post Rake Room						
Site: Post Rake Room									Site: Post Cl2 Tank						
Sample Characteristics		Hg	Cr	Cu	Pb	Ni	Zn	CN-	Hg	Cr	Cu	Pb	Ni	Zn	CN-
Sample Number		CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720	CO71900	CO1032	CO1042	CO1051	CO1074	CO1092	CO0720
Sample Type	Permit Condition	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
	Monitored	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	Grab	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour
Frequency	Permit Condition	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
	Monitored	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days	6 X Annual	4 X Annual	2-31 Days	4 X Annual	4 X Annual	4 X Annual	2-31 Days
Parameter Limits	Daily Maximum										0.055				0.016
	Monthly Average										0.024				0.016
1st Date :	September 7th		<0.005	0.093	0.015	0.015	0.100	<0.005		<0.005	0.020	0.003	<0.002	0.055	<0.005
2nd Date :	September 14th			0.120							0.018				
3rd Date :	September 21st		<0.005	0.098	0.012	0.015	0.110	<0.005			0.014				<0.005
4th Date :	September 28th			0.098							0.025				
5th Date :															
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	0	NA	NA	NA	0
Average			<0.003	0.102	0.014	0.015	0.105	<0.003		<0.003	0.019	0.003	<0.001	0.055	<0.003
Maximum			<0.005	0.120	0.015	0.015	0.110	<0.005		<0.005	0.025	0.003	<0.002	0.055	<0.005

* We are currently under Agreed Order 2000-9996-W with IDEM to resolve effluent copper concerns.

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (/100mL)	Mnthly Av Escherichia Coliform (/100mL)
Limit	None	None	30	20	2504	1669	36	24	3004	2003	2.40	1.60	200	134	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0
Max	3.8	2.9	6	4	194	116	12	8	385	229	2.53	0.83	86	27	7.5	7.72	< 0.01	148	21
Total				0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0

*Dissolved Oxygen value is minimum daily average

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Sep-05
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Page 6 of 6
 Permit # IN0025577
 Expires 10-31-2009
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Total lbs Volatile Solids to Digester 1,098

Overall Percent Removal of Volatile Solids 35.5%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 19,609

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 475

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 80

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 1,055

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 20

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 3

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 2

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	38%	53%	6%
Secondary Treatment :	84%	65%	61%
Adv. Sec. Treatment :	67%	59%	90%
Overall Treatment :	97%	93%	96%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	7.1	2.0	4.1
Secondary Settling Tank	5.2	1.5	3.0
Final Settling Tank	16.4	4.6	9.5
Total Plant Retention Time	28.7	8.1	16.7

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	762	215	368
Secondary Settling Tank	1005	284	486
Final Settling Tank	512	145	248

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	15	4	7
Secondary Settling Tank	12	3	6
Final Settling Tank	12	3	6

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

September 7, 13 - Successful Generator Load Test

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines or imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____

