

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-15
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 1 of 6
 Permit # IN0025577
 Expires 12-31-2014
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

					Raw Sewage				Primary Effluent				Secondary Effluent				Rotary Filter		Fixed-Bed Filter		Trickling Filters	Biotowers					
Day of the Month	Day of the Week	Total Flow in MGal/Day	Weekly Average Flow MGal/Day	Precip in inches	Collection System Overflow 'X' if occurred	Diversion to CSO Basin At site hours	CSO Basin Overflow in MGal/Day	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	pH	CBOD in mg/L	TSS in mg/L	NH3 in mg/L	Flow in MG/Day	Cleaning in Minutes	Flow in MG/Day	Cleaning in Minutes	Secondary Recirc. Ratio	Flow in MG/Day	Tertiary Recirc. Ratio	Cleaning in Minutes
1	Sun	4.7		0.02			0.00	7.50	82	68	11.70	7.44	73	80	13.35	7.49	16	25	10.30	4.4		2.1		0.38	7.0	0.48	
2	Mon	3.5					0.00	7.55	118	94	17.80	7.48	72	44	15.90	7.49	13	20	10.95	4.5		2.2		0.90	5.1	0.43	90
3	Tue	3.4					0.00	7.59	115	122	17.80	7.44	118	52	19.90	7.30	15	18	14.30	4.5		2.2		1.00	4.8	0.43	
4	Wed	4.5					0.00	7.70	153	176	17.40	7.44	88	34	15.25	7.44	16	20	12.50	4.5		2.2		0.48	6.9	0.51	
5	Thu	3.1		0.04			0.00	7.47	101	72	12.25	7.46	89	72	25.80	7.46	15	30	18.20	4.4	60	1.9		1.03	4.8	0.56	
6	Fri	3.7					0.00	7.56	125	164	30.40	7.55	82	68	24.70	7.43	16	26	18.50	4.5		1.7	120	0.68	5.2	0.41	
7	Sat	4.7	4.0	0.13			0.00	7.65	155	196	21.30	7.46	76	84	15.80	7.29	24	36	13.00	5.2		2.5		0.62	6.7	0.42	
8	Sun	4.9		0.02			0.00	7.56	115	180	14.00	7.50	78	68	12.15	7.40	25	32	8.45	4.9		2.7		0.54	7.1	0.44	
9	Mon	4.6					0.00	7.62	120	248	11.20	7.44	71	62	12.30	7.39	16	28	9.25	4.5		2.7		0.57	6.6	0.43	
10	Tue	3.2					0.00	7.50	72	83	10.10	7.45	111	74	21.00	7.26	19	21	13.60	4.5		2.3		1.13	3.9	0.21	
11	Wed	3.9					0.00	7.57	165	118	19.30	7.48	84	66	27.00	7.44	17	23	18.20	4.5		2.9		0.91	6.2	0.59	
12	Thu	3.8					0.00	7.60	98	87	18.40	7.55	73	62	16.60	7.54	15	27	14.50	4.5		3.7		1.16	4.7	0.23	
13	Fri	3.4					0.00	7.59	120	104	40.50	7.53	100	84	23.90	7.49	14	24	18.75	4.4		3.7	120	1.40	4.2	0.25	
14	Sat	4.4	4.0	0.02			0.00	7.62	160	366	24.80	7.57	72	50	16.20	7.41	20	22	12.80	4.5		3.6		0.83	6.5	0.47	
15	Sun	3.0					0.00	7.62	107	108	13.70	7.53	100	68	18.10	7.42	18	31	12.70	4.5		2.7		1.42	4.3	0.43	
16	Mon	3.7					0.00	7.63	130	117	27.80	7.48	105	64	18.80	7.34	21	20	16.00	4.5		2.8		0.95	5.5	0.46	
17	Tue	4.0					0.00	7.48	128	90	15.40	7.39	71	50	18.00	7.34	14	23	12.90	4.6		2.7		0.84	5.7	0.43	
18	Wed	3.0					0.00	7.61	130	183	22.60	7.48	105	54	29.20	7.43	16	18	22.30	4.6		2.2		1.24	4.3	0.40	
19	Thu	4.3					0.00	7.63	92	88	15.90	7.54	79	60	22.20	7.55	21	26	18.90	4.5		3.3		0.82	6.7	0.57	
20	Fri	3.3					0.00	7.65	200	174	21.50	7.53	93	73	25.70	7.49	19	28	19.90	4.5		1.9		0.92	5.1	0.53	
21	Sat	3.5	3.5				0.00	7.55	180	94	17.50	7.47	97	54	19.20	7.42	28	20	15.40	4.5		1.7		0.78	5.5	0.57	
22	Sun	3.9					0.00	7.57	117	134	13.20	7.50	64	54	13.60	7.49	14	25	10.10	4.5		2.1		0.67	4.7	0.19	
23	Mon	3.0					0.00	7.57	155	117	36.00	7.47	91	60	26.10	7.41	17	25	19.15	4.5		2.2		1.26	4.8	0.62	
24	Tue	4.3					0.00	7.69	134	198	14.80	7.50	94	56	19.20	7.44	21	25	17.60	4.5		2.2		0.58	6.8	0.59	
25	Wed	3.4					0.00	7.62	124	116	31.25	7.45	96	56	21.00	7.47	25	18	16.00	4.5		2.2		0.98	4.1	0.19	
26	Thu	3.3		0.01			0.00	7.74	135	74	24.50	7.58	100	60	24.75	7.43	21	18	22.80	4.4		1.9		0.89	5.5	0.66	
27	Fri	4.0		0.01			0.00	7.71	143	112	32.20	7.68	89	57	22.00	7.45	19	21	19.70	4.5		1.7	90	0.57	5.3	0.33	
28	Sat	3.0	3.6				0.00	7.71	73	112	20.40	7.61	100	68	20.50	7.53	14	23	15.00	4.5		1.7		1.09	3.8	0.28	
AVERAGE		3.8		0.01		0.0	0.00	7.60	127	136	20.49	7.50	88	62	19.94	7.43	18	24	15.42	4.5	2	2.4	12	0.88	5.4	0.43	3
MAXIMUM		4.9	4.0	0.13		0.0	0.00	7.74	200	366	40.50	7.68	118	84	29.20	7.55	28	36	22.80	5.2	60	3.7	120	1.42	7.1	0.66	90
MINIMUM		3.0		0.00		0.0	0.00	7.47	72	68	10.10	7.39	64	34	12.15	7.26	13	18	8.45	4.4	60	1.7	90	0.38	3.8	0.19	90
# OF DATA		28		28		28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	1	28	3		28		1
TOTAL		106		0.25			0	213	3546	3795	574	210	2472	1734	558	208	508	672	432	127	60	68	330		152		90

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 2 of 6

Date: Feb-15 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Permit # IN0025577
 Expires 12-31-2014
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Final Effluent

Day of the Month	Day of the Week	Effluent Flow in MGal/Day	Maximum Daily pH	Minimum Daily pH	CBOD in mg/L	CBOD weekly av in mg/L	CBOD in lbs/Day	CBOD weekly av in lbs/Day	TSS in mg/L	TSS weekly av in mg/L	TSS in lbs/Day	TSS weekly av in lbs/Day	NH3-N in mg/L	NH3-N weekly av in mg/L	NH3-N in lbs/Day	NH3-N weekly av in lbs/Day	Dissolved Oxygen in mg/L	Aerators run in hours	Chlorine Tank Residual in mg/L	Escherichia Coliform (Colonies /100mL)	Effluent Chlorine Residual in mg/L
1	Sun	4.6	7.56	7.34	7		283		11		413		0.22		9		13.1				
2	Mon	3.5	7.50	7.21	6		178		10		296		0.19		6		12.7				
3	Tue	3.4	7.53	7.34	6		160		8		211		0.21		6		12.4				
4	Wed	4.5	7.50	7.18	8		291		6		227		0.30		11		13.0				
5	Thu	3.2	7.60	7.42	6		143		14		363		0.27		7		13.3				
6	Fri	3.6	7.53	7.39	8		237		14		431		0.59		18		12.7				
7	Sat	4.6	7.50	7.29	9	7	360	236	13	11	514	351	0.48	0.32	19	11	12.6				
8	Sun	4.8	7.69	7.41	15		594		13		512		0.14		6		12.6				
9	Mon	4.6	7.48	7.34	13		488		15		576		0.11		4		13.4				
10	Tue	3.3	7.61	7.18	11		292		11		292		0.15		4		13.1				
11	Wed	3.8	7.52	7.31	6		191		12		388		0.52		17		12.6				
12	Thu	3.9	7.61	7.43	6		189		14		441		0.67		21		14.0				
13	Fri	3.4	7.57	7.38	6		155		10		283		0.51		14		13.9				
14	Sat	4.4	7.66	7.42	9	9	339	321	12	12	443	419	0.38	0.35	14	11	13.9				
15	Sun	3.1	7.62	7.45	8		189		15		373		0.24		6		14.0				
16	Mon	3.7	7.51	7.06	6		197		11		343		0.26		8		13.7				
17	Tue	4.0	7.48	7.32	7		224		12		379		0.28		9		13.8				
18	Wed	3.2	7.61	7.23	7		180		1		25		0.46		12		13.8				
19	Thu	4.3	7.58	7.46	9		337		13		448		0.74		27		13.3				
20	Fri	3.5	7.55	7.21	7		186		12		333		0.80		22		14.5				
21	Sat	3.6	7.56	7.35	9	8	268	226	1	9	29	276	0.63	0.49	18	15	13.5				
22	Sun	3.9	7.63	7.44	8		272		5		164		0.27		9		13.9				
23	Mon	3.1	7.57	7.37	7		182		9		224		0.27		7		14.3				
24	Tue	4.2	7.50	7.21	9		320		10		355		0.64		23		13.5				
25	Wed	3.5	7.54	7.44	7		190		13		368		0.42		12		12.5				
26	Thu	3.4	7.51	7.37	5		142		4		111		0.51		14		13.0				
27	Fri	4.0	7.47	7.40	6		198		10		331		1.25		41		13.6				
28	Sat	3.1	7.52	7.41	10	8	256	223	8	8	199	250	0.53	0.56	13	17	13.1				
AVERAGE		3.8			8		251		10		324		0.43		13		13.4				
MAXIMUM		4.8	7.69		15	9	594	321	15	12	576	419	1.25	0.56	41	17	14.5				
MINIMUM		3.1		7.06	5		142		1		25		0.11		4		12.4				
# OF DATA		28	28	28	28		28		28		28		28		28		28				
TOTAL		106	211	205	220		7041		285		9072		12		377		373.8				

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-15

LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 3 of 6

Permit # IN0025577

Expires 12-31-2014

Certified Operator : Jerry P Jackson

Certification Number : 11496

Solids Removal

		Chemicals Used for disinfection			Primary & Secondary Settling				Final Settling		
Day of the Month	Day of the Week	Chlorine in lbs/Day	Sulfur Dioxide in lbs/Day	Grit in cubic ft per day	Screening in cubic ft per day	Pri. Sludge to Primary # 1 Digester (gal x 1000)	Scum to Primary # 2 Digester (gal x 1000)	Secondary Sludge to Pri. Clarifier (gal x 1000)	Cleaning Mechanism run in hours	Sludge Drawn Hours per day	Sludge to Headworks (gal x 1000)
1	Sun					20	0	251	6	2	78
2	Mon					21	0	241	6	2	78
3	Tue					20	0	240	6	2	77
4	Wed					21	0	246	6	2	81
5	Thu					21	0	240	6	2	78
6	Fri					20	0	242	6	2	77
7	Sat					20	0	248	6	2	78
8	Sun					25	0	247	6	2	76
9	Mon			27	41	22	0	253	6	2	78
10	Tue					21	0	246	6	2	80
11	Wed					21	0	249	6	2	79
12	Thu					21	0	246	6	2	77
13	Fri					20	0	243	6	2	78
14	Sat					25	0	247	6	2	81
15	Sun					20	0	242	6	2	91
16	Mon					20	0	245	6	2	88
17	Tue					21	0	244	6	2	77
18	Wed					21	0	240	6	2	79
19	Thu					20	0	245	6	2	78
20	Fri				27	20	0	240	6	2	78
21	Sat					20	0	241	6	2	78
22	Sun					22	0	243	6	2	77
23	Mon					22	0	240	6	2	78
24	Tue					21	0	247	6	2	77
25	Wed					22	0	245	6	2	77
26	Thu					21	0	247	6	2	78
27	Fri				27	20	0	257	6	2	77
28	Sat					16	0	261	6	2	78
AVERAGE				1	3	21		245	6	2	79
MAXIMUM				27	41	25		261	6	2	91
MINIMUM				27	27	16	0	240	6	2	76
# OF DATA				1	3	28	28	28	28	28	28
TOTAL				27	95	587		6874	168	63	2209

Secondary Digester		Date:
<i>Sample Taken by Grab Method</i>		
Pollutants:	Wet Wght	Dry Wght
Inorganic	mg/L	mg/Kg
Arsenic - As		
Cadmium - Cd		
Chromium - Cr		
Copper - Cu		
Lead - Pb		
Mercury - Hg		
Molybdenum - Mo		
Nickel - Ni		
Selenium - Se		
Zinc - Zn		
% Total Solids		

Nutrients	Wet Wght	% by
	mg/L	weight
TKN		
Ammonia		
Nitrate		
Phosphorous		
Potassium		

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 4 of 6

Permit # IN0025577

Expires 12-31-2014

Certified Operator : Jerry P Jackson

Certification Number : 11496

Date: Feb-15

LaPorte Wastewater Treatment Plant

2101 Boyd Boulevard, La Porte IN 46350

Phone # (219)362-2354

			Raw Sludge			Primary Digester #1				Primary Digester #2				Secondary Digester					Digested Sludge Storage Tank				
Day of the Month	Day of the Week	Gas produced in 1000 cubic ft per day	Total Solids in percent	Solids Percent Volatile	pH	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Total Solids in percent	Solids Percent Volatile	pH	Digester Temp in Deg. F	Sludge to Secondary Digester (gal x 1000)	Total Solids in percent	Solids Percent Volatile	pH	Digester Overflow Supernatant (gal x 1000)	Digester Supernatant (% Total Solids)	Storage Tank #1 Volume (gal x 1000)	Storage Tank #2 Volume (gal x 1000)	Storage Tank Supernatant (gal x 1000)	Secondary to Storage Tank (gal x 1000)
1	Sun								91					28				49	0.73		103		
2	Mon		2.23	84.3	6.46	2.42	62.6	6.91	91	1.20	62.5	6.90	97	25	3.34	64.8	6.97	11			130		27
3	Tue								91				97	11				4			130		
4	Wed								91				97	24				43			131		
5	Thu								91				97	35				56			130		
6	Fri								91				97	40				60			131		
7	Sat								91				97	26				56			130		
8	Sun								91				97	23				45			130		
9	Mon		3.55	81.1	6.46	1.25	64.2	7.04	91	1.39	65.0	7.15	97	31	3.17	65.1	7.17	5			161		31
10	Tue								91				97	27				48			162		
11	Wed								91				97	28				54			162		
12	Thu								91				97	13				37			162		
13	Fri								91				97	21				41			162		
14	Sat								91				97	24				46			162		
15	Sun								91				97	27				54	1.66		163		
16	Mon		2.51	84.6	6.77	2.54	62.1	6.98	91	1.52	61.8	6.89	97	23	3.39	58.9	6.95	15			186		23
17	Tue								91				97	15				8			185		
18	Wed								91				97	28				51			186		
19	Thu								91				97	28				40			186		
20	Fri								90				97	25				44			186		
21	Sat								90				97	21				40			186		
22	Sun								90				97	19				37			186		
23	Mon		2.73	80.7	6.70	2.14	64.8	7.08	90	1.27	63.1	6.98	97	42	3.42	60.6	7.00	21			216		30
24	Tue								90				97	25				49			216		
25	Wed								90				97	18				30			216		
26	Thu								90				97	26				46			216		
27	Fri								90				97	18				35			216		
28	Sat								90				97	13				34			216		
AVERAGE			2.76	82.7	6.60	2.09	63.4	7.00	91	1.35	63.1	6.98	97	24	3.33	62.4	7.02	38	1.20		170		4
MAXIMUM			3.55	84.6	6.77	2.54	64.8	7.08	91	1.52	65.0	7.15	97	42	3.42	65.1	7.17	60	1.66		216		31
MINIMUM			2.23	80.7	6.46	1.25	62.1	6.91	90	1.20	61.8	6.89	97	11	3.17	58.9	6.95	4	0.73		103		
# OF DATA			4	4	4	4	4	4	28	4	4	4	28	28	4	4	4	28	2	28	28		28
TOTAL			11	331	26	8	254	28	2535	5	252	28	2715	683	13	249	28	1062	2		4747		111

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Date: Feb-15
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard
 LaPorte IN, 46350
 Phone # (219)362-2354

Page 5 of 6
 Permit # IN0025577
 Expires 12-31-2014
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

NPDES LIMITS AND ANALYSIS

Metals and Cyanide Analysis : All results are given in mg/l

INFLUENT								EFFLUENT							
Method: 24 hour composite								Site: Post Disinfection							
Sample Characteristics		Cr	Cu	Pb	Ni	Zn	CN, Free	Cr	Cu	Pb	Ni	Zn	CN, Free		
Sample Number															
Sample Type	Permit Condition	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB		
	Monitored	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB	24 Hour	24 Hour	24 Hour	24 Hour	24 Hour	GRAB		
Frequency	Permit Condition	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual		
	Monitored	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual	4 X Annual		
Parameter Limits	Daily Maximum	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
	Monthly Average	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
1st Date:	February 4th	0.009	0.049	<0.005	0.008	0.066		<0.005	0.019	<0.005	<0.005	0.047			
2nd Date :	February 18th	0.027	0.180	<0.005	0.017	0.081	<0.002	<0.005	0.031	<0.005	<0.005	0.032	<0.002		
3rd Date	February 25th		0.047						0.026						
4th Date :															
5th Date															
Number of times Limit Value exceeded:		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
Average		0.018	0.092	<0.003	0.013	0.074	<0.001	<0.003	0.025	<0.003	<0.003	0.040	<0.001		
Maximum		0.027	0.180	<0.005	0.017	0.081	<0.002	<0.005	0.031	<0.005	<0.005	0.047	<0.002		

Other Permit Analysis

	Weekly Av FLOW in MGD	Monthly Average FLOW in MGD	Weekly Av CBOD in mg/L	Monthly Average CBOD in mg/L	Weekly Av CBOD in lbs/Day	Monthly Average CBOD in lbs/Day	Weekly Av TSS in mg/L	Monthly Average TSS in mg/L	Weekly Av TSS in lbs/Day	Monthly Average TSS in lbs/Day	Weekly Av NH3-N in mg/L	Monthly Average NH3-N in mg/L	Weekly Av NH3-N in lbs/Day	Monthly Average NH3-N in lbs/Day	Daily Dissolved Oxygen* in mg/L	pH	Chlorine Residual in mg/L	Daily Max Escherichia Coliform (Colonies /100mL)	Mnthly Av Escherichia Coliform (Colonies /100mL)
Limit	None	None	40	25	3338	2086	45	30	3755	2504	2.70	1.80	225	150	6.0	6-9	0.06	235	125
Times Violated	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Max	4.0	3.8	9	8	321	251	12	10	419	324	0.56	0.43	17	13	12.4	7.69			
% of Limit	57%	54%	23%	31%	10%	12%	27%	34%	11%	13%	21%	24%	8%	9%	207%				
Total				0		0		0		0		0		0	0	0	0		0

*Dissolved Oxygen value is minimum daily average. Percent of limit values for Dissolved Oxygen less than 100% are indicative of a violation.

MONTHLY REPORT OF OPERATION

Trickling Filter Wastewater Treatment Plant

Page 6 of 6
 Permit # IN0025577
 Expires 12-31-2014
 Certified Operator : Jerry P Jackson
 Certification Number : 11496

Date: Feb-15
 LaPorte Wastewater Treatment Plant
 2101 Boyd Boulevard, La Porte IN 46350
 Phone # (219)362-2354

Total lbs Volatile Solids to Digester 3,983

Overall Percent Removal of Volatile Solids 65.3%

Equivalent Population Treated in (lbs Raw CBOD per Day / 0.17) 23,426

Rotary Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 429

Fixed Bed Filter Hydraulic Loading Rate (Gallon / Day / Sq Ft) 56

Biotower Filter Hydraulic Loading Rate (Gallons / Day / Sq Ft) 703

Rotary Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 29

Fixed Bed Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Biotower Filter Organic Loading Rate (lbs CBOD / 1000 Cu Ft / Day) 4

Monthly Removal Summary

Percent Removal :	CBOD	TSS	AMMONIA
Primary Treatment :	30%	54%	3%
Secondary Treatment :	79%	61%	23%
Adv. Sec. Treatment :	57%	58%	97%
Overall Treatment :	94%	93%	98%

Detention Time (Hours)	Maximum	Minimum	Average
Primary Settling Tank	4.1	2.5	3.2
Secondary Settling Tank	3.0	1.8	2.4
Final Settling Tank	9.4	5.7	7.5
Chlorine Contact Tank	0.65	0.39	0.51
Total Plant Retention Time	16.5	10.0	13.1

Surface Flow Rate			
Gallons per sq ft per Day	Maximum	Minimum	Average
Primary Settling Tank	614	373	471
Secondary Settling Tank	810	492	622
Final Settling Tank	413	251	317

Weir OverFlow Rate			
1000 Gal per ft per Day	Maximum	Minimum	Average
Primary Settling Tank	12	7	9
Secondary Settling Tank	10	6	7
Final Settling Tank	9	6	7

TREATMENT EQUIPMENT	Total available	Number in service
PRIMARY CLARIFIER TANKS	4	4
SECONDARY CLARIFIER TANKS	2	2
FINAL CLARIFIER TANKS	2	2
ROTARY FILTER	1	1
FIXED BED FILTER	1	1
BIOTOWERS	2	2

Monthly Comments Concerning Plant Operation:

3/9/2015 - Successful test of plant operation on emergency generator power
 3/23/2015 - Successful test of plant operation on emergency generator power

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of linear imprisonment for knowing violations.

Certified Operator Signature: _____ Certification # : 11496

Executive Officer OR Authorized Agent Signature: _____



**National Pollutant Discharge Elimination System (NPDES)
CSO Monthly Report of Operation (CSO MRO)**

State Form 50546 (R3 / 7-13)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

City: La Porte		Page: 1 of 2		Permit Number: IN0025577																
Facility: La Porte Wastewater Treatment Facility		Public Notification Requirements Met? Y																		
Monitoring Period: February 2015		Check box if no CSO discharge occurred for the month:			X															
Design Peak Inf. Flow(MGD) 9.7		Design Average Flow (M) 7.0		Measured/Metered (M) or Estimated (E) must be specified.																
WWTP Influent Data		Precipitation Data			CSO Outfall No. 002		CSO Outfall No.													
Day of Month	Avg Infl. Flow Rate (MGD)	Peak Infl. Flow Rate (MGD)	Time Precip. began (AM/PM)	Precip. Duration (HOURS)	Total Daily Precip. (inches)	Peak Intensity (Inch/Hr)	Measurement Interval (hr, 30min, 15min)	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	Time Discharge Began	M or E	Event Duration (Hours)	M or E	Event Discharge (MG)	M or E	
1	4.72	5.50	12:00 AM	0.0	0.02	0.01	HR													
2	3.55	4.92																		
3	3.38	5.44																		
4	4.53	5.29																		
5	3.11	3.72	0:52 PM	0.1	0.04	0.03	HR													
6	3.69	5.63																		
7	4.74	8.36	10:55 AM	0.2	0.13	0.08	HR													
8	4.91	7.66	12:00 AM	0.0	0.02	0.02	HR													
9	4.61	5.47																		
10	3.19	3.88																		
11	3.87	5.58																		
12	3.77	5.05																		
13	3.39	4.66																		
14	4.42	5.20	12:00 AM	0.0	0.02	0.01	HR													
15	2.98	3.91																		
16	3.74	5.31																		
17	3.95	5.06																		
18	3.04	3.93																		
19	4.29	5.46																		
20	3.32	5.01																		
21	3.49	5.33																		
22	3.93	5.09																		
23	2.98	3.67																		
24	4.26	5.47																		
25	3.40	5.18																		
26	3.34	4.96			0.01	0.01	HR													
27	3.97	5.67			0.01	0.00	HR													
28	2.98	3.66																		
29																				
30																				
31																				
Totals:		105.57		0.37	0.25					0.0										
Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent													Telephone							
Jerry P Jackson, Superintendent													219-362-2354							
I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.																				
Signature of Principal Executive Officer or Authorized Agent													Date							
													06/15/2015							



**National Pollutant Discharge Elimination System (NPDES)
CSO Monthly Report of Operation (CSO MRO)**

State Form 50546 (R3 / 7-13)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

City:	La Porte	Page: 2 of	2	Permit Number:	IN0025577
Facility:	La Porte Wastewater Treatment Facility	Public Notification Requirements Met? Y			
Monitoring Period:	February 2015	Check box if no CSO discharge occurred for the month:			X
Design Peak Inf. Flow(MGD)	9.7	Design Average Flow (M	7.0		

Day of Month	Comments (further explanation as to why each CSO event occurred)
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	

Typed or Printed Name and Title of Principal Executive Officer of Authorized Agent	Telephone
Jerry P Jackson, Superintendent	219-362-2354
<p>I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHEMENTS WERE PREPARED UNDER MY DIRECTION OF SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSONS WHO MANAGE THE SYSTEM OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION; THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.</p>	
Signature of Principal Executive Officer or Authorized Agent	Date
	06/15/2015